

**Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Ockley Green Middle School**

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
178-2752-A-002-A Boiler Room	11/15/18 6:06 AM	11/19/18 2:17 PM	18030326	Copper	< 0.1	1.3	ppm
178-2752-A-002-A Boiler Room	11/15/18 6:06 AM	11/19/18 2:17 PM	18030326	Lead	13	15	ppb
178-2752-A-002-B Boiler Room	11/15/18 6:07 AM	11/19/18 2:18 PM	18030330	Copper	< 0.1	1.3	ppm
178-2752-A-002-B Boiler Room	11/15/18 6:07 AM	11/19/18 2:18 PM	18030330	Lead	4	15	ppb
178-2730-A-002-A Fac Kitchen 130	11/15/18 6:11 AM	11/19/18 2:19 PM	18030329	Copper	0.2	1.3	ppm
178-2730-A-002-A Fac Kitchen 130	11/15/18 6:11 AM	11/19/18 2:19 PM	18030329	Lead	7	15	ppb
178-2730-A-002-B Fac Kitchen 130	11/15/18 6:12 AM	11/19/18 2:21 PM	18030332	Copper	0.1	1.3	ppm
178-2730-A-002-B Fac Kitchen 130	11/15/18 6:12 AM	11/19/18 2:21 PM	18030332	Lead	< 1	15	ppb
178-2736-A-002-A Classroom 102	11/15/18 6:16 AM	11/19/18 2:22 PM	18030327	Copper	0.4	1.3	ppm
178-2736-A-002-A Classroom 102	11/15/18 6:16 AM	11/19/18 2:22 PM	18030327	Lead	3	15	ppb
178-2736-A-002-B Classroom 102	11/15/18 6:17 AM	11/19/18 2:23 PM	18030325	Copper	0.3	1.3	ppm
178-2736-A-002-B Classroom 102	11/15/18 6:17 AM	11/19/18 2:23 PM	18030325	Lead	< 1	15	ppb
178-2739-A-002-A Classroom 104	11/15/18 6:30 AM	11/19/18 2:35 PM	18030331	Copper	0.4	1.3	ppm
178-2739-A-002-A Classroom 104	11/15/18 6:30 AM	11/19/18 2:35 PM	18030331	Lead	10	15	ppb
178-2739-A-002-B Classroom 104	11/15/18 6:31 AM	11/19/18 2:36 PM	18030328	Copper	0.3	1.3	ppm
178-2739-A-002-B Classroom 104	11/15/18 6:31 AM	11/19/18 2:36 PM	18030328	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper