

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Peninsula

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
180-CH2274-NA-002-A	Kitchen	10/11/2018	10/18/2018	A8J0428-03	Copper	0.231	0.00200	1.3	ppm
180-CH2274-NA-002-A	Kitchen	10/11/2018	10/18/2018	A8J0428-03	Lead	8.65	0.200	15	ppb
180-CH2274-NA-002-B	Kitchen	10/11/2018	10/18/2018	A8J0428-04	Copper	0.246	0.00200	1.3	ppm
180-CH2274-NA-002-B	Kitchen	10/11/2018	10/18/2018	A8J0428-04	Lead	0.585	0.200	15	ppb
180-CH2920-A-002-A	Kitchen	10/11/2018	10/18/2018	A8J0428-01	Copper	0.156	0.00200	1.3	ppm
180-CH2920-A-002-A	Kitchen	10/11/2018	10/18/2018	A8J0428-01	Lead	1.48	0.200	15	ppb
180-CH2920-A-002-B	Kitchen	10/11/2018	10/18/2018	A8J0428-02	Copper	0.263	0.00200	1.3	ppm
180-CH2920-A-002-B	Kitchen	10/11/2018	10/18/2018	A8J0428-02	Lead	0.222	0.200	15	ppb
180-CH2972-NA-002-A	Classroom 107	10/11/2018	10/18/2018	A8J0428-17	Copper	0.766	0.00200	1.3	ppm
180-CH2972-NA-002-A	Classroom 107	10/11/2018	10/18/2018	A8J0428-17	Lead	3.65	0.200	15	ppb
180-CH2972-NA-002-B	Classroom 107	10/11/2018	10/18/2018	A8J0428-18	Copper	0.820	0.00200	1.3	ppm
180-CH2972-NA-002-B	Classroom 107	10/11/2018	10/18/2018	A8J0428-18	Lead	1.83	0.200	15	ppb
180-CH2984-NA-002-A	Classroom 104	10/11/2018	10/18/2018	A8J0428-19RE1	Copper	1.02	0.0200	1.3	ppm
180-CH2984-NA-002-A	Classroom 104	10/11/2018	10/18/2018	A8J0428-19	Lead	5.25	0.200	15	ppb
180-CH2984-NA-002-B	Classroom 104	10/11/2018	10/18/2018	A8J0428-20RE1	Copper	1.04	0.0200	1.3	ppm
180-CH2984-NA-002-B	Classroom 104	10/11/2018	10/18/2018	A8J0428-20	Lead	1.61	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

180-CH2987-NA-002-A	Classroom 103	10/11/2018	10/18/2018	A8J0428-23RE1	Copper	1.98	0.0200	1.3	ppm
180-CH2987-NA-002-A	Classroom 103	10/11/2018	10/18/2018	A8J0428-23	Lead	25.8	0.200	15	ppb
180-CH2987-NA-002-B	Classroom 103	10/11/2018	10/18/2018	A8J0428-24RE1	Copper	2.36	0.0200	1.3	ppm
180-CH2987-NA-002-B	Classroom 103	10/11/2018	10/18/2018	A8J0428-24	Lead	4.34	0.200	15	ppb
180-CH2990-NA-002-A	Classroom 102	10/11/2018	10/18/2018	A8J0428-21	Copper	0.895	0.00200	1.3	ppm
180-CH2990-NA-002-A	Classroom 102	10/11/2018	10/18/2018	A8J0428-21	Lead	6.46	0.200	15	ppb
180-CH2990-NA-002-B	Classroom 102	10/11/2018	10/18/2018	A8J0428-22RE1	Copper	1.06	0.0200	1.3	ppm
180-CH2990-NA-002-B	Classroom 102	10/11/2018	10/18/2018	A8J0428-22	Lead	1.70	0.200	15	ppb
180-CH2993-NA-002-A	Classroom 100	10/11/2018	10/18/2018	A8J0428-25	Copper	0.834	0.00200	1.3	ppm
180-CH2993-NA-002-A	Classroom 100	10/11/2018	10/18/2018	A8J0428-25	Lead	6.35	0.200	15	ppb
180-CH2993-NA-002-B	Classroom 100	10/11/2018	10/18/2018	A8J0428-26	Copper	0.883	0.00200	1.3	ppm
180-CH2993-NA-002-B	Classroom 100	10/11/2018	10/18/2018	A8J0428-26	Lead	1.20	0.200	15	ppb
180-CH2996-NA-002-A	Classroom 101	10/11/2018	10/18/2018	A8J0428-27	Copper	0.968	0.00200	1.3	ppm
180-CH2996-NA-002-A	Classroom 101	10/11/2018	10/18/2018	A8J0428-27	Lead	23.9	0.200	15	ppb
180-CH2996-NA-002-B	Classroom 101	10/11/2018	10/18/2018	A8J0428-28	Copper	0.931	0.00200	1.3	ppm
180-CH2996-NA-002-B	Classroom 101	10/11/2018	10/18/2018	A8J0428-28	Lead	31.1	0.200	15	ppb
180-CH3000-NA-002-A	Classroom 119	10/11/2018	10/18/2018	A8J0428-37	Copper	0.754	0.00200	1.3	ppm
180-CH3000-NA-002-A	Classroom 119	10/11/2018	10/18/2018	A8J0428-37	Lead	2.10	0.200	15	ppb
180-CH3000-NA-002-B	Classroom 119	10/11/2018	10/18/2018	A8J0428-38	Copper	0.867	0.00200	1.3	ppm
180-CH3000-NA-002-B	Classroom 119	10/11/2018	10/18/2018	A8J0428-38	Lead	0.871	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

180-CH3002-NA-002-A	Hallway by Café	10/11/2018	10/18/2018	A8J0428-05RE1	Copper	2.96	0.0200	1.3	ppm
180-CH3002-NA-002-A	Hallway by Café	10/11/2018	10/18/2018	A8J0428-05	Lead	2.85	0.200	15	ppb
180-CH3002-NA-002-B	Hallway by Café	10/11/2018	10/18/2018	A8J0428-06RE1	Copper	2.02	0.0200	1.3	ppm
180-CH3002-NA-002-B	Hallway by Café	10/11/2018	10/18/2018	A8J0428-06	Lead	8.88	0.200	15	ppb
180-CH3006-NA-002-A	Classroom 123	10/11/2018	10/18/2018	A8J0428-39RE1	Copper	2.23	0.0200	1.3	ppm
180-CH3006-NA-002-A	Classroom 123	10/11/2018	10/18/2018	A8J0428-39	Lead	79.9	0.200	15	ppb
180-CH3006-NA-002-B	Classroom 123	10/11/2018	10/18/2018	A8J0428-40RE1	Copper	2.19	0.0200	1.3	ppm
180-CH3006-NA-002-B	Classroom 123	10/11/2018	10/18/2018	A8J0428-40	Lead	63.9	0.200	15	ppb
180-CH3009-NA-002-A	Classroom 124	10/11/2018	10/18/2018	A8J0428-41	Copper	0.735	0.00200	1.3	ppm
180-CH3009-NA-002-A	Classroom 124	10/11/2018	10/18/2018	A8J0428-41	Lead	3.52	0.200	15	ppb
180-CH3009-NA-002-B	Classroom 124	10/11/2018	10/18/2018	A8J0428-42	Copper	0.786	0.00200	1.3	ppm
180-CH3009-NA-002-B	Classroom 124	10/11/2018	10/18/2018	A8J0428-42	Lead	1.11	0.200	15	ppb
180-CH3010-NA-002-A	Classroom 113	10/11/2018	10/18/2018	A8J0428-07	Copper	0.621	0.00200	1.3	ppm
180-CH3010-NA-002-A	Classroom 113	10/11/2018	10/18/2018	A8J0428-07	Lead	3.50	0.200	15	ppb
180-CH3010-NA-002-B	Classroom 113	10/11/2018	10/18/2018	A8J0428-08	Copper	0.531	0.00200	1.3	ppm
180-CH3010-NA-002-B	Classroom 113	10/11/2018	10/18/2018	A8J0428-08	Lead	1.26	0.200	15	ppb
180-CH3014-NA-002-A	Classroom 117	10/11/2018	10/18/2018	A8J0428-29	Copper	0.814	0.00200	1.3	ppm
180-CH3014-NA-002-A	Classroom 117	10/11/2018	10/18/2018	A8J0428-29	Lead	2.86	0.200	15	ppb
180-CH3014-NA-002-B	Classroom 117	10/11/2018	10/18/2018	A8J0428-30	Copper	0.756	0.00200	1.3	ppm
180-CH3014-NA-002-B	Classroom 117	10/11/2018	10/18/2018	A8J0428-30	Lead	0.532	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

180-CH3015-NA-002-A	Classroom 127	10/11/2018	10/18/2018	A8J0428-43	Copper	0.837	0.00200	1.3	ppm
180-CH3015-NA-002-A	Classroom 127	10/11/2018	10/18/2018	A8J0428-43	Lead	5.38	0.200	15	ppb
180-CH3015-NA-002-B	Classroom 127	10/11/2018	10/18/2018	A8J0428-44	Copper	0.884	0.00200	1.3	ppm
180-CH3015-NA-002-B	Classroom 127	10/11/2018	10/18/2018	A8J0428-44	Lead	2.40	0.200	15	ppb
180-CH3016-NA-002-A	Classroom 112	10/11/2018	10/18/2018	A8J0428-09	Copper	0.871	0.00200	1.3	ppm
180-CH3016-NA-002-A	Classroom 112	10/11/2018	10/18/2018	A8J0428-09	Lead	10.7	0.200	15	ppb
180-CH3016-NA-002-B	Classroom 112	10/11/2018	10/18/2018	A8J0428-10RE1	Copper	1.02	0.0200	1.3	ppm
180-CH3016-NA-002-B	Classroom 112	10/11/2018	10/18/2018	A8J0428-10	Lead	2.34	0.200	15	ppb
180-CH3017-NA-002-A	Classroom 118	10/11/2018	10/18/2018	A8J0428-31	Copper	0.882	0.00200	1.3	ppm
180-CH3017-NA-002-A	Classroom 118	10/11/2018	10/18/2018	A8J0428-31	Lead	11.9	0.200	15	ppb
180-CH3017-NA-002-B	Classroom 118	10/11/2018	10/18/2018	A8J0428-32RE1	Copper	1.16	0.0200	1.3	ppm
180-CH3017-NA-002-B	Classroom 118	10/11/2018	10/18/2018	A8J0428-32	Lead	12.8	0.200	15	ppb
180-CH3018-NA-002-A	Classroom 128	10/11/2018	10/18/2018	A8J0428-45	Copper	0.824	0.00200	1.3	ppm
180-CH3018-NA-002-A	Classroom 128	10/11/2018	10/18/2018	A8J0428-45	Lead	6.08	0.200	15	ppb
180-CH3018-NA-002-B	Classroom 128	10/11/2018	10/18/2018	A8J0428-46	Copper	0.755	0.00200	1.3	ppm
180-CH3018-NA-002-B	Classroom 128	10/11/2018	10/18/2018	A8J0428-46	Lead	1.35	0.200	15	ppb
180-CH3019-NA-002-A	Classroom 111	10/11/2018	10/18/2018	A8J0428-11	Copper	0.719	0.00200	1.3	ppm
180-CH3019-NA-002-A	Classroom 111	10/11/2018	10/18/2018	A8J0428-11	Lead	4.41	0.200	15	ppb
180-CH3019-NA-002-B	Classroom 111	10/11/2018	10/18/2018	A8J0428-12	Copper	0.725	0.00200	1.3	ppm
180-CH3019-NA-002-B	Classroom 111	10/11/2018	10/18/2018	A8J0428-12	Lead	1.05	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

180-CH3022-NA-002-A	Classroom 110	10/11/2018	10/18/2018	A8J0428-13	Copper	0.895	0.00200	1.3	ppm
180-CH3022-NA-002-A	Classroom 110	10/11/2018	10/18/2018	A8J0428-13	Lead	4.06	0.200	15	ppb
180-CH3022-NA-002-B	Classroom 110	10/11/2018	10/18/2018	A8J0428-14RE1	Copper	1.01	0.0200	1.3	ppm
180-CH3022-NA-002-B	Classroom 110	10/11/2018	10/18/2018	A8J0428-14	Lead	1.18	0.200	15	ppb
180-CH3023-NA-002-A	Classroom 120	10/11/2018	10/18/2018	A8J0428-35	Copper	0.615	0.00200	1.3	ppm
180-CH3023-NA-002-A	Classroom 120	10/11/2018	10/18/2018	A8J0428-35	Lead	8.56	0.200	15	ppb
180-CH3023-NA-002-B	Classroom 120	10/11/2018	10/18/2018	A8J0428-36	Copper	0.466	0.00200	1.3	ppm
180-CH3023-NA-002-B	Classroom 120	10/11/2018	10/18/2018	A8J0428-36	Lead	1.87	0.200	15	ppb
180-CH3024-NA-002-A	Staff Room 34A	10/11/2018	10/18/2018	A8J0428-33RE1	Copper	1.37	0.0200	1.3	ppm
180-CH3024-NA-002-A	Staff Room 34A	10/11/2018	10/18/2018	A8J0428-33	Lead	75.0	0.200	15	ppb
180-CH3024-NA-002-B	Staff Room 34A	10/11/2018	10/18/2018	A8J0428-34	Copper	0.671	0.00200	1.3	ppm
180-CH3024-NA-002-B	Staff Room 34A	10/11/2018	10/18/2018	A8J0428-34	Lead	2.94	0.200	15	ppb
180-CH3025-NA-002-A	Classroom 108	10/11/2018	10/18/2018	A8J0428-15	Copper	0.947	0.00200	1.3	ppm
180-CH3025-NA-002-A	Classroom 108	10/11/2018	10/18/2018	A8J0428-15	Lead	6.14	0.200	15	ppb
180-CH3025-NA-002-B	Classroom 108	10/11/2018	10/18/2018	A8J0428-16RE1	Copper	1.06	0.0200	1.3	ppm
180-CH3025-NA-002-B	Classroom 108	10/11/2018	10/18/2018	A8J0428-16	Lead	2.12	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.