

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Peninsula - Test # 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
180-CH3012-N/A-003-A	Classroom 126	3/26/2019	4/9/2019	A9C1079-01	Lead	3.36	0.20	15	ppb
180-CH3003-N/A-003-A	Classroom 121	3/26/2019	4/9/2019	A9C1079-03	Lead	0.702	0.20	15	ppb
180-CH3008-N/A-003-A	Gym	3/26/2019	4/9/2019	A9C1079-05	Lead	2.25	0.20	15	ppb
180-CH3021-A-003-A	Hallway (Office/Cafeteria)	3/26/2019	4/9/2019	A9C1079-07	Lead	3.14	0.20	15	ppb
180-CH3021-B-003-A	Hallway (Office/Cafeteria)	3/26/2019	4/9/2019	A9C1079-09	Lead	0.694	0.20	15	ppb
180-CH3007-N/A-003-A	Classroom 115	3/26/2019	4/9/2019	A9C1079-11	Lead	10.8	0.20	15	ppb
180-CH3001-N/A-003-A	Staff Workroom 120	3/26/2019	4/9/2019	A9C1079-13	Lead	ND	0.20	15	ppb
180-CH2978-N/A-003-A	Classroom 106	3/26/2019	4/9/2019	A9C1079-15	Lead	1.49	0.20	15	ppb
180-CH2981-N/A-003-A	Classroom 105	3/26/2019	4/9/2019	A9C1079-17	Lead	42.40	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.