

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Peninsula K-5 School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
180-CH2920-N/A-004-A	Kitchen	5/21/2019	5/28/2019	A9E0811-03	Lead	1.37	0.20	15	ppb