

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Holladay Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
306-1362-A-001A Entry Drink. Fount.	08/07/18 6:47 AM	08/08/18 5:35 PM	18018019	Copper	0.4	1.3	ppm
306-1362-A-001A Entry Drink. Fount.	08/07/18 6:47 AM	08/08/18 5:35 PM	18018019	Lead	< 1	15	ppb
306-1362-A-001B Entry Drink. Fount.	08/07/18 6:47 AM	08/08/18 5:37 PM	18018021	Copper	0.4	1.3	ppm
306-1362-A-001B Entry Drink. Fount.	08/07/18 6:47 AM	08/08/18 5:37 PM	18018021	Lead	< 1	15	ppb
306-2263-A-001A Kitchen Left Dbl. Sink	08/07/18 6:53 AM	08/10/18 12:56 PM	18018022	Copper	0.6	1.3	ppm
306-2263-A-001A Kitchen Left Dbl. Sink	08/07/18 6:53 AM	08/10/18 12:56 PM	18018022	Lead	22	15	ppb
306-2263-A-001B Kitchen Left Dbl. Sink	08/07/18 6:53 AM	08/09/18 6:06 PM	18018020	Copper	0.7	1.3	ppm
306-2263-A-001B Kitchen Left Dbl. Sink	08/07/18 6:53 AM	08/08/18 5:55 PM	18018020	Lead	< 1	15	ppb
306-2264-A-001A Kitchen Right Dbl. Sink	08/07/18 6:57 AM	08/10/18 1:00 PM	18018023	Copper	0.4	1.3	ppm
306-2264-A-001A Kitchen Right Dbl. Sink	08/07/18 6:57 AM	08/10/18 1:00 PM	18018023	Lead	19	15	ppb
306-2264-A-001B Kitchen Right Dbl. Sink	08/07/18 6:57 AM	08/09/18 6:10 PM	18018024	Copper	0.6	1.3	ppm
306-2264-A-001B Kitchen Right Dbl. Sink	08/07/18 6:57 AM	08/08/18 5:57 PM	18018024	Lead	< 1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.