

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Pioneer Program at Holladay Center - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
306-CH1353-N/A-003-A	Hallway (25)	3/29/2019	4/9/2019	A9C1065-01	Lead	17.20	0.20	15	ppb
306-CH1364-N/A-003-A	Hallway (28)	3/29/2019	4/9/2019	A9C1065-03	Lead	27.10	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.