

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Pioneer Program at Holladay Center - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
306-CH1353-N/A-004-A	Hallway (28)	5/22/2019	5/28/2019	A9E0811-06	Lead	3.79	0.20	15	ppb
306-CH1364-N/A-004-A	Hallway (25)	5/22/2019	5/28/2019	A9E0811-07	Lead	7.42	0.20	15	ppb