

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Holladay Annex - Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
362-CH2265-N/A-001-A	Hallway (32)	5/1/2019	5/14/2019	A9E0112-01	Lead	15.00	0.20	15	ppb
362-CH1369-N/A-001-A	Hallway (32)	5/1/2019	5/14/2019	A9E0112-02	Lead	2.45	0.20	15	ppb
362-CH1372-A-001-A	Staff Room 68	5/1/2019	5/14/2019	A9E0112-03	Lead	0.822	0.20	15	ppb
362-CH1372-B-001-A	Staff Room 68	5/1/2019	5/14/2019	A9E0112-04	Lead	ND	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.