Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Youngson School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
298-1322-A-001A Gym Drink FT	08/07/18 6:25 AM	08/08/18 5:30 PM	18018015	Copper	0.3	1.3	ppm
298-1322-A-001A Gym Drink FT	08/07/18 6:25 AM	08/08/18 5:30 PM	18018015	Lead	2	15	ppb
298-1322-A-001B Gym Drink FT	08/07/18 6:25 AM	08/08/18 5:32 PM	18018017	Copper	0.2	1.3	ppm
298-1322-A-001B Gym Drink FT	08/07/18 6:25 AM	08/08/18 5:32 PM	18018017	Lead	< 1	15	ppb
298-1352-A-001A Kitchen Doub. Sink	08/07/18 6:32 AM	08/10/18 12:52 PM	18018016	Copper	0.3	1.3	ppm
298-1352-A-001A Kitchen Doub. Sink	08/07/18 6:32 AM	08/10/18 12:52 PM	18018016	Lead	15	15	ppb
298-1352-A-001B Kitchen Doub. Sink	08/07/18 6:32 AM	08/08/18 5:33 PM	18018018	Copper	0.3	1.3	ppm
298-1352-A-001B Kitchen Doub. Sink	08/07/18 6:32 AM	08/08/18 5:33 PM	18018018	Lead	< 1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Pixis Labs
Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper