

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Youngson Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
298-CH1352-N/A-003-A	Kitchen	3/22/2019	3/29/2019	A9C0796-01	Lead	ND	0.20	15	ppb
298-CH1315-N/A-003-A	Classroom 10	3/22/2019	3/29/2019	A9C0796-08	Lead	3.52	0.20	15	ppb