

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rice- Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
274-CH3840-N/A-001-A	Staff Room 9	3/27/2019	4/10/2019	A9C1082-01	Lead	3.01	0.20	15	ppb
274-CH3837-N/A-001-A	Staff Room 8	3/27/2019	4/10/2019	A9C1082-03	Lead	4.7	0.20	15	ppb
274-CH3860-N/A-001-A	Hallway (1)	3/27/2019	4/10/2019	A9C1082-05	Lead	10.7	0.20	15	ppb
274-CH3857-A-001-A	Storeroom 1	3/27/2019	4/10/2019	A9C1082-07	Lead	39.00	0.20	15	ppb
274-CH3857-B-001-A	Storeroom 1	3/27/2019	4/10/2019	A9C1082-09	Lead	47.80	0.20	15	ppb
274-CH3781-A-001-A	Staff Room 1	3/27/2019	4/10/2019	A9C1082-11	Lead	7.3	0.20	15	ppb
274-CH3781-B-001-A	Staff Room 1	3/27/2019	4/10/2019	A9C1082-13	Lead	0.849	0.20	15	ppb
274-CH3836-N/A-001-A	Faculty Room	3/27/2019	4/10/2019	A9C1082-15	Lead	10.5	0.20	15	ppb
274-CH3851-A-001-A	Staff Room 2	3/27/2019	4/10/2019	A9C1082-17	Lead	2.97	0.20	15	ppb
274-CH3851-B-001-A	Staff Room 2	3/27/2019	4/10/2019	A9C1082-19	Lead	3.62	0.20	15	ppb
274-CH3839-A-001-A	Staff Room 7	3/27/2019	4/10/2019	A9C1082-21	Lead	5.08	0.20	15	ppb
274-CH3845-A-001-A	Staff Room 6	3/27/2019	4/10/2019	A9C1082-23	Lead	4.62	0.20	15	ppb
274-CH3845-B-001-A	Staff Room 6	3/27/2019	4/10/2019	A9C1082-25	Lead	8.36	0.20	15	ppb
274-CH3842-A-001-A	Staff Room 3	3/27/2019	4/10/2019	A9C1082-27	Lead	9.61	0.20	15	ppb
274-CH3848-A-001-A	Staff Room 5	3/27/2019	4/10/2019	A9C1082-29	Lead	5.79	0.20	15	ppb
274-CH3848-B-001-A	Staff Room 5	3/27/2019	4/10/2019	A9C1082-31	Lead	1.03	0.20	15	ppb
274-CH3854-A-001-A	Staff Room 4	3/27/2019	4/10/2019	A9C1082-33	Lead	12.9	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15 ppb

274-CH3854-B-001-A	Staff Room 4	3/27/2019	4/10/2019	A9C1082-35	Lead	1.48	0.20	15	ppb
--------------------	--------------	-----------	-----------	------------	------	------	------	----	-----

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15 ppb