

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Richmond**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
275-CH1335-A-001-A	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-21	Copper	0.465	0.00100	1.3	ppm
275-CH1335-A-001-A	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-21	Lead	2.19	0.200	15	ppb
275-CH1335-A-001-B	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-22	Copper	0.331	0.00100	1.3	ppm
275-CH1335-A-001-B	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-22	Lead	1.20	0.200	15	ppb
275-CH1335-B-001-A	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-23	Copper	0.628	0.00100	1.3	ppm
275-CH1335-B-001-A	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-23	Lead	2.50	0.200	15	ppb
275-CH1335-B-001-B	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-24	Copper	0.326	0.00100	1.3	ppm
275-CH1335-B-001-B	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-24	Lead	1.20	0.200	15	ppb
275-CH1337-A-001-A	Hallway Bubbler	10/28/2017 10:26	11/9/2017	A7J0943-25	Copper	0.413	0.00100	1.3	ppm
275-CH1337-A-001-A	Hallway Bubbler	10/28/2017 10:26	11/9/2017	A7J0943-25	Lead	1.68	0.200	15	ppb
275-CH1337-A-001-B	Hallway Bubbler	10/28/2017 10:26	11/9/2017	A7J0943-26	Copper	0.271	0.00100	1.3	ppm
275-CH1337-A-001-B	Hallway Bubbler	10/28/2017 10:26	11/9/2017	A7J0943-26	Lead	0.263	0.200	15	ppb
275-CH1337-B-001-A	Hallway Bubbler	10/28/2017 10:28	11/9/2017	A7J0943-27	Copper	0.514	0.00100	1.3	ppm
275-CH1337-B-001-A	Hallway Bubbler	10/28/2017 10:28	11/9/2017	A7J0943-27RE2	Lead	ND	0.800	15	ppb
275-CH1337-B-001-B	Hallway Bubbler	10/28/2017 10:28	11/9/2017	A7J0943-28	Copper	0.169	0.00100	1.3	ppm
275-CH1337-B-001-B	Hallway Bubbler	10/28/2017 10:28	11/9/2017	A7J0943-28	Lead	0.230	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 4

275-CH1340-N/A-001-A	Hallway Bubbler	10/28/2017 10:35	11/9/2017	A7J0943-29	Copper	0.545	0.00100	1.3	ppm
275-CH1340-N/A-001-A	Hallway Bubbler	10/28/2017 10:35	11/9/2017	A7J0943-29	Lead	1.90	0.200	15	ppb
275-CH1340-N/A-001-B	Hallway Bubbler	10/28/2017 10:35	11/9/2017	A7J0943-30	Copper	0.316	0.00100	1.3	ppm
275-CH1340-N/A-001-B	Hallway Bubbler	10/28/2017 10:35	11/9/2017	A7J0943-30	Lead	0.603	0.200	15	ppb
275-CH1342-A-001-A	Hallway Bubbler	10/28/2017 10:41	11/9/2017	A7J0943-31	Copper	0.719	0.00100	1.3	ppm
275-CH1342-A-001-A	Hallway Bubbler	10/28/2017 10:41	11/9/2017	A7J0943-31	Lead	1.60	0.200	15	ppb
275-CH1342-A-001-B	Hallway Bubbler	10/28/2017 10:41	11/9/2017	A7J0943-32	Copper	0.567	0.00100	1.3	ppm
275-CH1342-A-001-B	Hallway Bubbler	10/28/2017 10:41	11/9/2017	A7J0943-32	Lead	0.382	0.200	15	ppb
275-CH1342-B-001-A	Hallway Bubbler	10/28/2017 10:42	11/9/2017	A7J0943-33	Copper	0.655	0.00100	1.3	ppm
275-CH1342-B-001-A	Hallway Bubbler	10/28/2017 10:42	11/9/2017	A7J0943-33	Lead	7.78	0.200	15	ppb
275-CH1342-B-001-B	Hallway Bubbler	10/28/2017 10:42	11/9/2017	A7J0943-34	Copper	0.315	0.00100	1.3	ppm
275-CH1342-B-001-B	Hallway Bubbler	10/28/2017 10:42	11/9/2017	A7J0943-34	Lead	0.313	0.200	15	ppb
275-CH1345-A-001-A	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-05	Copper	0.418	0.00100	1.3	ppm
275-CH1345-A-001-A	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-05	Lead	4.48	0.200	15	ppb
275-CH1345-A-001-B	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-06	Copper	0.307	0.00100	1.3	ppm
275-CH1345-A-001-B	Hallway Bubbler	10/28/2017 10:15	11/9/2017	A7J0943-06	Lead	1.34	0.200	15	ppb
275-CH1345-B-001-A	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-07	Copper	0.372	0.00100	1.3	ppm
275-CH1345-B-001-A	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-07	Lead	3.96	0.200	15	ppb
275-CH1345-B-001-B	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-08	Copper	0.307	0.00100	1.3	ppm
275-CH1345-B-001-B	Hallway Bubbler	10/28/2017 10:17	11/9/2017	A7J0943-08	Lead	1.24	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 2 of 4

275-CH1350-N/A-001-A	Hallway Bubbler	10/28/2017 9:28	11/9/2017	A7J0943-03	Copper	0.470	0.00100	1.3	ppm
275-CH1350-N/A-001-A	Hallway Bubbler	10/28/2017 9:28	11/9/2017	A7J0943-03	Lead	1.08	0.200	15	ppb
275-CH1350-N/A-001-B	Hallway Bubbler	10/28/2017 9:28	11/9/2017	A7J0943-04	Copper	0.156	0.00100	1.3	ppm
275-CH1350-N/A-001-B	Hallway Bubbler	10/28/2017 9:28	11/9/2017	A7J0943-04	Lead	0.316	0.200	15	ppb
275-CH1739-N/A-001-A	Hallway Bubbler	10/28/2017 9:22	11/9/2017	A7J0943-01	Copper	0.596	0.00100	1.3	ppm
275-CH1739-N/A-001-A	Hallway Bubbler	10/28/2017 9:22	11/9/2017	A7J0943-01RE1	Lead	10.7	0.200	15	ppb
275-CH1739-N/A-001-B	Hallway Bubbler	10/28/2017 9:22	11/9/2017	A7J0943-02	Copper	0.361	0.00100	1.3	ppm
275-CH1739-N/A-001-B	Hallway Bubbler	10/28/2017 9:22	11/9/2017	A7J0943-02RE1	Lead	0.702	0.200	15	ppb
275-CH1811-N/A-001-A	Hallway Bubbler	10/28/2017 9:45	11/9/2017	A7J0943-09	Copper	0.634	0.00100	1.3	ppm
275-CH1811-N/A-001-A	Hallway Bubbler	10/28/2017 9:45	11/9/2017	A7J0943-09	Lead	0.883	0.200	15	ppb
275-CH1811-N/A-001-B	Hallway Bubbler	10/28/2017 9:45	11/9/2017	A7J0943-10	Copper	0.345	0.00100	1.3	ppm
275-CH1811-N/A-001-B	Hallway Bubbler	10/28/2017 9:45	11/9/2017	A7J0943-10	Lead	ND	0.200	15	ppb
275-CH1814-N/A-001-A	Cafeteria Bubbler	10/28/2017 9:51	11/9/2017	A7J0943-11	Copper	0.459	0.00100	1.3	ppm
275-CH1814-N/A-001-A	Cafeteria Bubbler	10/28/2017 9:51	11/9/2017	A7J0943-11	Lead	1.44	0.200	15	ppb
275-CH1814-N/A-001-B	Cafeteria Bubbler	10/28/2017 9:51	11/9/2017	A7J0943-12	Copper	0.343	0.00100	1.3	ppm
275-CH1814-N/A-001-B	Cafeteria Bubbler Kitchen Prep Sink	10/28/2017 9:51	11/9/2017	A7J0943-12	Lead	1.42	0.200	15	ppb
275-CH1823-A-001-A	Attachment Kitchen Prep Sink	10/28/2017 9:59	11/9/2017	A7J0943-13	Copper	0.305	0.00100	1.3	ppm
275-CH1823-A-001-A	Attachment Kitchen Prep Sink	10/28/2017 9:59	11/9/2017	A7J0943-13	Lead	1.08	0.200	15	ppb
275-CH1823-A-001-B	Attachment Kitchen Prep Sink	10/28/2017 9:59	11/9/2017	A7J0943-14	Copper	0.349	0.00100	1.3	ppm
275-CH1823-A-001-B	Attachment	10/28/2017 9:59	11/9/2017	A7J0943-14	Lead	0.238	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

275-CH1823-B-001-A	Kitchen Prep Sink	10/28/2017 10:01	11/9/2017	A7J0943-15	Copper	0.341	0.00100	1.3	ppm
275-CH1823-B-001-A	Kitchen Prep Sink	10/28/2017 10:01	11/9/2017	A7J0943-15	Lead	0.453	0.200	15	ppb
275-CH1823-B-001-B	Kitchen Prep Sink	10/28/2017 10:01	11/9/2017	A7J0943-16	Copper	0.355	0.00100	1.3	ppm
275-CH1823-B-001-B	Kicthen Prep Sink	10/28/2017 10:01	11/9/2017	A7J0943-16	Lead	ND	0.200	15	ppb
275-CH2262-A-001-A	Hallway Bubbler	10/28/2017 10:12	11/9/2017	A7J0943-17	Copper	0.498	0.00100	1.3	ppm
275-CH2262-A-001-A	Hallway Bubbler	10/28/2017 10:12	11/9/2017	A7J0943-17	Lead	2.41	0.200	15	ppb
275-CH2262-A-001-B	Hallway Bubbler	10/28/2017 10:12	11/9/2017	A7J0943-18	Copper	0.383	0.00100	1.3	ppm
275-CH2262-A-001-B	Hallway Bubbler	10/28/2017 10:12	11/9/2017	A7J0943-18	Lead	0.871	0.200	15	ppb
275-CH2262-B-001-A	Hallway Bubbler	10/28/2017 10:14	11/9/2017	A7J0943-19	Copper	0.552	0.00100	1.3	ppm
275-CH2262-B-001-A	Hallway Bubbler	10/28/2017 10:14	11/9/2017	A7J0943-19	Lead	2.06	0.200	15	ppb
275-CH2262-B-001-B	Hallway Bubbler	10/28/2017 10:14	11/9/2017	A7J0943-20	Copper	0.363	0.00100	1.3	ppm
275-CH2262-B-001-B	Hallway Bubbler	10/28/2017 10:14	11/9/2017	A7J0943-20	Lead	1.22	0.200	15	ppb

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 4 of 4