

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Richmond Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
275-1341-N/A-001-A	Drinking Fountain (Metal) - Hallway by 209	8/9/2018	8/23/2018	A8H0250-01RE3	Copper	0.966	0.0200	1.3	ppm
275-1341-N/A-001-A	Drinking Fountain (Metal) - Hallway by 209	8/9/2018	8/16/2018	A8H0250-01	Lead	8.91	0.200	15	ppb
275-1341-N/A-001-B	Drinking Fountain (Metal) - Hallway by 209	8/9/2018	8/17/2018	A8H0250-02RE1	Copper	0.411	0.00200	1.3	ppm
275-1341-N/A-001-B	Drinking Fountain (Metal) - Hallway by 209	8/9/2018	8/16/2018	A8H0250-02	Lead	5.40	0.200	15	ppb
275-1343-N/A-001-A	Sink Bubbler - Classroom 201	8/9/2018	8/17/2018	A8H0250-03RE1	Copper	0.747	0.00200	1.3	ppm
275-1343-N/A-001-A	Sink Bubbler - Classroom 201	8/9/2018	8/16/2018	A8H0250-03	Lead	7.75	0.200	15	ppb
275-1343-N/A-001-B	Sink Bubbler - Classroom 201	8/9/2018	8/17/2018	A8H0250-04RE1	Copper	0.745	0.00200	1.3	ppm
275-1343-N/A-001-B	Sink Bubbler - Classroom 201	8/9/2018	8/16/2018	A8H0250-04	Lead	1.59	0.200	15	ppb
275-1344-N/A-001-A	Sink Bubbler - Classroom 200	8/9/2018	8/17/2018	A8H0250-05RE1	Copper	0.283	0.00200	1.3	ppm
275-1344-N/A-001-A	Sink Bubbler - Classroom 200	8/9/2018	8/16/2018	A8H0250-05	Lead	4.91	0.200	15	ppb
275-1344-N/A-001-B	Sink Bubbler - Classroom 200	8/9/2018	8/17/2018	A8H0250-06RE1	Copper	0.599	0.00200	1.3	ppm
275-1344-N/A-001-B	Sink Bubbler - Classroom 200	8/9/2018	8/16/2018	A8H0250-06	Lead	1.54	0.200	15	ppb
275-1334-N/A-001-A	Sink Bubbler - Kindergarten 24	8/9/2018	8/17/2018	A8H0250-07RE1	Copper	0.403	0.00200	1.3	ppm
275-1334-N/A-001-A	Sink Bubbler - Kindergarten 24	8/9/2018	8/16/2018	A8H0250-07	Lead	4.63	0.200	15	ppb
275-1334-N/A-001-B	Sink Bubbler - Kindergarten 24	8/9/2018	8/16/2018	A8H0250-08	Copper	0.634	0.00200	1.3	ppm
275-1334-N/A-001-B	Sink Bubbler - Kindergarten 24	8/9/2018	8/16/2018	A8H0250-08	Lead	1.72	0.200	15	ppb
275-1348-N/A-001-A	Sink Bubbler - Classroom 102	8/9/2018	8/16/2018	A8H0250-09	Copper	0.907	0.00200	1.3	ppm
275-1348-N/A-001-A	Sink Bubbler - Classroom 102	8/9/2018	8/16/2018	A8H0250-09	Lead	20.5	0.200	15	ppb
275-1348-N/A-001-B	Sink Bubbler - Classroom 102	8/9/2018	8/16/2018	A8H0250-10	Copper	0.689	0.00200	1.3	ppm
275-1348-N/A-001-B	Sink Bubbler - Classroom 102	8/9/2018	8/16/2018	A8H0250-10	Lead	3.68	0.200	15	ppb
275-1347-N/A-001-A	Sink Bubbler - Classroom 103	8/9/2018	8/16/2018	A8H0250-11	Copper	0.709	0.00200	1.3	ppm
275-1347-N/A-001-A	Sink Bubbler - Classroom 103	8/9/2018	8/16/2018	A8H0250-11	Lead	10.7	0.200	15	ppb
275-1347-N/A-001-B	Sink Bubbler - Classroom 103	8/9/2018	8/16/2018	A8H0250-12	Copper	0.320	0.00200	1.3	ppm
275-1347-N/A-001-B	Sink Bubbler - Classroom 103	8/9/2018	8/16/2018	A8H0250-12	Lead	3.14	0.200	15	ppb
275-1351-N/A-001-A	Sink Bubbler - Classroom 106	8/9/2018	8/16/2018	A8H0250-13	Copper	0.620	0.00200	1.3	ppm

275-1351-N/A-001-A	Sink Bubbler - Classroom 106	8/9/2018	8/16/2018	A8H0250-13	Lead	5.36	0.200	15	ppb
275-1351-N/A-001-B	Sink Bubbler - Classroom 106	8/9/2018	8/16/2018	A8H0250-14	Copper	0.489	0.00200	1.3	ppm
275-1351-N/A-001-B	Sink Bubbler - Classroom 106	8/9/2018	8/16/2018	A8H0250-14	Lead	1.03	0.200	15	ppb
275-2260-A-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/28/2018	A8H0250-15RE4	Copper	1.15	0.0200	1.3	ppm
275-2260-A-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-15	Lead	11.4	0.200	15	ppb
275-2260-A-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-16	Copper	0.553	0.00200	1.3	ppm
275-2260-A-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-16	Lead	3.20	0.200	15	ppb
275-2260-B-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-17	Copper	0.898	0.00200	1.3	ppm
275-2260-B-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-17	Lead	5.86	0.200	15	ppb
275-2260-B-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/17/2018	A8H0250-18RE1	Copper	0.355	0.00200	1.3	ppm
275-2260-B-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/17/2018	A8H0250-18RE1	Lead	1.59	0.200	15	ppb
275-2261-A-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-19	Copper	0.562	0.00200	1.3	ppm
275-2261-A-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-19	Lead	8.98	0.200	15	ppb
275-2261-A-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-20	Copper	0.224	0.00200	1.3	ppm
275-2261-A-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-20	Lead	1.85	0.200	15	ppb
275-2261-B-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-21	Copper	0.644	0.00200	1.3	ppm
275-2261-B-001-A	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-21	Lead	9.59	0.200	15	ppb
275-2261-B-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-22	Copper	0.256	0.00200	1.3	ppm
275-2261-B-001-B	Drinking Fountain (Porcelain) - Media/Library	8/9/2018	8/16/2018	A8H0250-22	Lead	2.57	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.