

**Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Rieke Elementary School**

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
183-4476-A-001A B/W Rms 14&15	08/03/18 8:45 AM	08/06/18 1:17 PM	18017583	Copper	<0.1	1.3	ppm
183-4476-A-001A B/W Rms 14&15	08/03/18 8:45 AM	08/06/18 1:17 PM	18017583	Lead	4	15	ppb
183-4476-A-001B B/W Rms 14&15	08/03/18 8:45 AM	08/06/18 1:35 PM	18017585	Copper	<0.1	1.3	ppm
183-4476-A-001B B/W Rms 14&15	08/03/18 8:45 AM	08/06/18 1:35 PM	18017585	Lead	3	15	ppb
183-4462-A-001A Kitchen	08/03/18 8:50 AM	08/06/18 1:37 PM	18017580	Copper	0.2	1.3	ppm
183-4462-A-001A Kitchen	08/03/18 8:50 AM	08/06/18 1:37 PM	18017580	Lead	1	15	ppb
183-4462-A-001B Kitchen	08/03/18 8:50 AM	08/06/18 1:39 PM	18017578	Copper	<0.1	1.3	ppm
183-4462-A-001B Kitchen	08/03/18 8:50 AM	08/06/18 1:39 PM	18017578	Lead	1	15	ppb
183-4459-A-001A Kitchen Faucet	08/03/18 8:52 AM	08/06/18 1:41 PM	18017579	Copper	<0.1	1.3	ppm
183-4459-A-001A Kitchen Faucet	08/03/18 8:52 AM	08/06/18 1:41 PM	18017579	Lead	5	15	ppb
183-4459-A-001B Kitchen Faucet	08/03/18 8:52 AM	08/06/18 1:42 PM	18017582	Copper	<0.1	1.3	ppm
183-4459-A-001B Kitchen Faucet	08/03/18 8:52 AM	08/06/18 1:42 PM	18017582	Lead	1	15	ppb
183-4459-B-001A Kitchen Sprayer	08/03/18 8:52 AM	08/06/18 1:44 PM	18017584	Copper	<0.1	1.3	ppm
183-4459-B-001A Kitchen Sprayer	08/03/18 8:52 AM	08/06/18 1:44 PM	18017584	Lead	2	15	ppb
183-4459-B-001B Kitchen Sprayer	08/03/18 8:52 AM	08/06/18 1:46 PM	18017581	Copper	<0.1	1.3	ppm
183-4459-B-001B Kitchen Sprayer	08/03/18 8:52 AM	08/06/18 1:46 PM	18017581	Lead	1	15	ppb
183-4465-A-001A Kitchen Faucet	08/03/18 8:57 AM	08/06/18 3:27 PM	18017586	Copper	1.1	1.3	ppm
183-4465-A-001A Kitchen Faucet	08/03/18 8:57 AM	08/06/18 1:48 PM	18017586	Lead	19	15	ppb
183-4465-A-001B Kitchen Faucet	08/03/18 8:57 AM	08/06/18 1:50 PM	18017587	Copper	<0.1	1.3	ppm
183-4465-A-001B Kitchen Faucet	08/03/18 8:57 AM	08/06/18 1:50 PM	18017587	Lead	1	15	ppb
183-4465-B-001A Kitchen Sprayer	08/03/18 8:57 AM	08/06/18 1:51 PM	18017588	Copper	0.1	1.3	ppm
183-4465-B-001A Kitchen Sprayer	08/03/18 8:57 AM	08/06/18 1:51 PM	18017588	Lead	1	15	ppb
183-4465-B-001B Kitchen Sprayer	08/03/18 8:57 AM	08/06/18 2:02 PM	18017589	Copper	<0.1	1.3	ppm
183-4465-B-001B Kitchen Sprayer	08/03/18 8:57 AM	08/06/18 2:02 PM	18017589	Lead	1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.