

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Rigler Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-1625-N/A-001-A	Food Prep Sprayer - Kitchen	7/30/2018	8/1/2018	A8G0782-01	Copper	0.123	0.00200	1.3	ppm
276-1625-N/A-001-A	Food Prep Sprayer - Kitchen	7/30/2018	8/1/2018	A8G0782-01	Lead	1.81	0.200	15	ppb
276-1625-N/A-001-B	Food Prep Sprayer - Kitchen	7/30/2018	8/1/2018	A8G0782-02	Copper	0.0424	0.00200	1.3	ppm
276-1625-N/A-001-B	Food Prep Sprayer - Kitchen	7/30/2018	8/1/2018	A8G0782-02	Lead	1.69	0.200	15	ppb
276-1626-N/A-001-A	Food Prep Faucet - Kitchen	7/30/2018	8/1/2018	A8G0782-03	Copper	0.0804	0.00200	1.3	ppm
276-1626-N/A-001-A	Food Prep Faucet - Kitchen	7/30/2018	8/1/2018	A8G0782-03	Lead	1.29	0.200	15	ppb
276-1626-N/A-001-B	Food Prep Faucet - Kitchen	7/30/2018	8/1/2018	A8G0782-04	Copper	0.0312	0.00200	1.3	ppm
276-1626-N/A-001-B	Food Prep Faucet - Kitchen	7/30/2018	8/1/2018	A8G0782-04	Lead	0.461	0.200	15	ppb
276-1628-N/A-001-A	Bubbler - Cafeteria	7/30/2018	8/1/2018	A8G0782-05	Copper	0.0940	0.00200	1.3	ppm
276-1628-N/A-001-A	Bubbler - Cafeteria	7/30/2018	8/1/2018	A8G0782-05	Lead	17.8	0.200	15	ppb
276-1628-N/A-001-B	Bubbler - Cafeteria	7/30/2018	8/1/2018	A8G0782-06	Copper	0.141	0.00200	1.3	ppm
276-1628-N/A-001-B	Bubbler - Cafeteria	7/30/2018	8/1/2018	A8G0782-06	Lead	26.7	0.200	15	ppb
276-1631-A-001-A	Bubbler Left - Cafeteria	7/30/2018	8/1/2018	A8G0782-07	Copper	0.154	0.00200	1.3	ppm
276-1631-A-001-A	Bubbler Left - Cafeteria	7/30/2018	8/1/2018	A8G0782-07	Lead	30.8	0.200	15	ppb
276-1631-A-001-B	Bubbler Left - Cafeteria	7/30/2018	8/1/2018	A8G0782-08	Copper	0.0844	0.00200	1.3	ppm
276-1631-A-001-B	Bubbler Left - Cafeteria	7/30/2018	8/1/2018	A8G0782-08	Lead	12.5	0.200	15	ppb
276-1631-B-001-A	Bubbler Right - Cafeteria	7/30/2018	8/1/2018	A8G0782-09	Copper	0.121	0.00200	1.3	ppm
276-1631-B-001-A	Bubbler Right - Cafeteria	7/30/2018	8/1/2018	A8G0782-09	Lead	25.1	0.200	15	ppb
276-1631-B-001-B	Bubbler Right - Cafeteria	7/30/2018	8/1/2018	A8G0782-10	Copper	0.0907	0.00200	1.3	ppm
276-1631-B-001-B	Bubbler Right - Cafeteria	7/30/2018	8/1/2018	A8G0782-10	Lead	12.4	0.200	15	ppb
276-1629-N/A-001-A	Bubbler - 43H Kitchen	7/30/2018	8/1/2018	A8G0782-11	Copper	0.0218	0.00200	1.3	ppm
276-1629-N/A-001-A	Bubbler - 43H Kitchen	7/30/2018	8/1/2018	A8G0782-11	Lead	2.19	0.200	15	ppb
276-1629-N/A-001-B	Bubbler - 43H Kitchen	7/30/2018	8/1/2018	A8G0782-12	Copper	0.0515	0.00200	1.3	ppm

276-1629-N/A-001-B	Bubbler - 43H Kitchen	7/30/2018	8/1/2018	A8G0782-12	Lead	0.663	0.200	15	ppb
276-1644-N/A-001-A	Drinking Fountain (Stainless) - By 14A	7/30/2018	8/1/2018	A8G0782-13	Copper	0.0125	0.00200	1.3	ppm
276-1644-N/A-001-A	Drinking Fountain (Stainless) - By 14A	7/30/2018	8/1/2018	A8G0782-13	Lead	4.72	0.200	15	ppb
276-1644-N/A-001-B	Drinking Fountain (Stainless) - By 14A	7/30/2018	8/1/2018	A8G0782-14	Copper	0.00461	0.00200	1.3	ppm
276-1644-N/A-001-B	Drinking Fountain (Stainless) - By 14A	7/30/2018	8/1/2018	A8G0782-14	Lead	3.67	0.200	15	ppb
276-1627-A-001-A	Bubbler Left - By 17 & 18	7/30/2018	8/1/2018	A8G0782-15	Copper	0.0299	0.00200	1.3	ppm
276-1627-A-001-A	Bubbler Left - By 17 & 18	7/30/2018	8/1/2018	A8G0782-15	Lead	13.2	0.200	15	ppb
276-1627-A-001-B	Bubbler Left - By 17 & 18	7/30/2018	8/1/2018	A8G0782-16	Copper	0.0257	0.00200	1.3	ppm
276-1627-A-001-B	Bubbler Left - By 17 & 18	7/30/2018	8/1/2018	A8G0782-16	Lead	4.31	0.200	15	ppb
276-1627-B-001-A	Bubbler Right - By 17 & 18	7/30/2018	8/1/2018	A8G0782-17	Copper	0.0344	0.00200	1.3	ppm
276-1627-B-001-A	Bubbler Right - By 17 & 18	7/30/2018	8/1/2018	A8G0782-17	Lead	23.5	0.200	15	ppb
276-1627-B-001-B	Bubbler Right - By 17 & 18	7/30/2018	8/1/2018	A8G0782-18	Copper	0.0274	0.00200	1.3	ppm
276-1627-B-001-B	Bubbler Right - By 17 & 18	7/30/2018	8/1/2018	A8G0782-18	Lead	3.67	0.200	15	ppb
276-1733-A-001-A	Bubbler Left - By 27A Office	7/30/2018	8/1/2018	A8G0782-19	Copper	0.0309	0.00200	1.3	ppm
276-1733-A-001-A	Bubbler Left - By 27A Office	7/30/2018	8/1/2018	A8G0782-19	Lead	11.2	0.200	15	ppb
276-1733-A-001-B	Bubbler Left - By 27A Office	7/30/2018	8/1/2018	A8G0782-20	Copper	0.0283	0.00200	1.3	ppm
276-1733-A-001-B	Bubbler Left - By 27A Office	7/30/2018	8/1/2018	A8G0782-20	Lead	1.06	0.200	15	ppb
276-1733-B-001-A	Bubbler Right - By 27A Office	7/30/2018	8/1/2018	A8G0782-21	Copper	0.0222	0.00200	1.3	ppm
276-1733-B-001-A	Bubbler Right - By 27A Office	7/30/2018	8/1/2018	A8G0782-21	Lead	3.63	0.200	15	ppb
276-1733-B-001-B	Bubbler Right - By 27A Office	7/30/2018	8/1/2018	A8G0782-22	Copper	0.0282	0.00200	1.3	ppm
276-1733-B-001-B	Bubbler Right - By 27A Office	7/30/2018	8/1/2018	A8G0782-22	Lead	0.837	0.200	15	ppb
276-1736-N/A-001-A	Drinking Fountain (Stainless) - By 23C	7/30/2018	8/1/2018	A8G0782-23	Copper	0.0121	0.00200	1.3	ppm
276-1736-N/A-001-A	Drinking Fountain (Stainless) - By 23C	7/30/2018	8/1/2018	A8G0782-23	Lead	1.88	0.200	15	ppb
276-1736-N/A-001-B	Drinking Fountain (Stainless) - By 23C	7/30/2018	8/1/2018	A8G0782-24	Copper	0.0338	0.00200	1.3	ppm
276-1736-N/A-001-B	Drinking Fountain (Stainless) - By 23C	7/30/2018	8/1/2018	A8G0782-24	Lead	8.36	0.200	15	ppb
276-1643-A-001-A	Bubbler Left - By Auditorium	7/30/2018	8/1/2018	A8G0782-25	Copper	0.0496	0.00200	1.3	ppm

276-1643-A-001-A	Bubbler Left - By Auditorium	7/30/2018	8/1/2018	A8G0782-25	Lead	7.96	0.200	15	ppb
276-1643-A-001-B	Bubbler Left - By Auditorium	7/30/2018	8/1/2018	A8G0782-26	Copper	0.0298	0.00200	1.3	ppm
276-1643-A-001-B	Bubbler Left - By Auditorium	7/30/2018	8/1/2018	A8G0782-26	Lead	19.3	0.200	15	ppb
276-1643-B-001-A	Bubbler Right - By Auditorium	7/30/2018	8/1/2018	A8G0782-27	Copper	0.0340	0.00200	1.3	ppm
276-1643-B-001-A	Bubbler Right - By Auditorium	7/30/2018	8/1/2018	A8G0782-27	Lead	8.33	0.200	15	ppb
276-1643-B-001-B	Bubbler Right - By Auditorium	7/30/2018	8/1/2018	A8G0782-28	Copper	0.0288	0.00200	1.3	ppm
276-1643-B-001-B	Bubbler Right - By Auditorium	7/30/2018	8/1/2018	A8G0782-28	Lead	20.2	0.200	15	ppb
276-1739-N/A-001-A	Drinking Fountain - Gym	7/30/2018	8/1/2018	A8G0782-29	Copper	0.0352	0.00200	1.3	ppm
276-1739-N/A-001-A	Drinking Fountain - Gym	7/30/2018	8/1/2018	A8G0782-29	Lead	51.1	0.200	15	ppb
276-1739-N/A-001-B	Drinking Fountain - Gym	7/30/2018	8/1/2018	A8G0782-30	Copper	0.0826	0.00200	1.3	ppm
276-1739-N/A-001-B	Drinking Fountain - Gym	7/30/2018	8/1/2018	A8G0782-30	Lead	33.2	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.