

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rigler Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
276-CH1624-N/A-004-A	Classroom 11A	4/30/2019	5/14/2019	A9E0102-01	Lead	27.80	0.20	15	ppb
276-CH1634-N/A-004-A	Hallway (31)	4/30/2019	5/14/2019	A9E0102-02	Lead	0.29	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.