

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Robert Gray Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
158-4404-A-001A Basement Boys Locker Rm	08/02/18 7:51 AM	08/07/18 5:32 PM	18017398	Copper	2.2	1.3	ppm
158-4404-A-001A Basement Boys Locker Rm	08/02/18 7:51 AM	08/06/18 6:28 PM	18017398	Lead	8	15	ppb
158-4404-A-001B Basement Boys Locker Rm	08/02/18 7:51 AM	08/07/18 5:37 PM	18017400	Copper	2.1	1.3	ppm
158-4404-A-001B Basement Boys Locker Rm	08/02/18 7:51 AM	08/06/18 6:52 PM	18017400	Lead	4	15	ppb
158-4407-A-001A Basement Girls Locker Rm	08/02/18 7:56 AM	08/07/18 5:41 PM	18017395	Copper	4.3	1.3	ppm
158-4407-A-001A Basement Girls Locker Rm	08/02/18 7:56 AM	08/06/18 6:53 PM	18017395	Lead	56	15	ppb
158-4407-A-001B Basement Girls Locker Rm	08/02/18 7:56 AM	08/07/18 5:45 PM	18017393	Copper	2.6	1.3	ppm
158-4407-A-001B Basement Girls Locker Rm	08/02/18 7:56 AM	08/06/18 6:55 PM	18017393	Lead	4	15	ppb
158-4427-A-001A Basement Gymnasium	08/02/18 8:01 AM	08/06/18 6:30 PM	18017394	Copper	0.9	1.3	ppm
158-4427-A-001A Basement Gymnasium	08/02/18 8:01 AM	08/06/18 6:30 PM	18017394	Lead	8	15	ppb
158-4427-A-001B Basement Gymnasium	08/02/18 8:01 AM	08/07/18 6:15 PM	18017397	Copper	1.2	1.3	ppm
158-4427-A-001B Basement Gymnasium	08/02/18 8:01 AM	08/06/18 6:32 PM	18017397	Lead	1	15	ppb
158-4406-A-001A Cafeteria	08/02/18 8:05 AM	08/07/18 6:19 PM	18017399	Copper	1.2	1.3	ppm
158-4406-A-001A Cafeteria	08/02/18 8:05 AM	08/06/18 6:33 PM	18017399	Lead	12	15	ppb
158-4406-A-001B Cafeteria	08/02/18 8:05 AM	08/07/18 6:24 PM	18017396	Copper	1.4	1.3	ppm
158-4406-A-001B Cafeteria	08/02/18 8:05 AM	08/06/18 6:35 PM	18017396	Lead	3	15	ppb
158-4411-A-001A Hallway near Cafeteria	08/02/18 8:10 AM	08/07/18 6:28 PM	18017401	Copper	3.1	1.3	ppm
158-4411-A-001A Hallway near Cafeteria	08/02/18 8:10 AM	08/06/18 6:37 PM	18017401	Lead	11	15	ppb
158-4411-A-001B Hallway near Cafeteria	08/02/18 8:10 AM	08/07/18 6:32 PM	18017402	Copper	3.1	1.3	ppm
158-4411-A-001B Hallway near Cafeteria	08/02/18 8:10 AM	08/06/18 6:39 PM	18017402	Lead	2	15	ppb
158-4414-A-001A Hallway near Room 98	08/02/18 8:15 AM	08/07/18 7:50 PM	18017403	Copper	0.1	1.3	ppm
158-4414-A-001A Hallway near Room 98	08/02/18 8:15 AM	08/07/18 7:50 PM	18017403	Lead	9	15	ppb
158-4414-A-001B Hallway near Room 98	08/02/18 8:15 AM	08/07/18 7:54 PM	18017404	Copper	<0.1	1.3	ppm
158-4414-A-001B Hallway near Room 98	08/02/18 8:15 AM	08/07/18 7:54 PM	18017404	Lead	6	15	ppb
158-4436-A-001A B Hallway near Room 114	08/02/18 8:35 AM	08/06/18 6:57 PM	18017405	Copper	0.8	1.3	ppm
158-4436-A-001A B Hallway near Room 114	08/02/18 8:35 AM	08/06/18 6:57 PM	18017405	Lead	8	15	ppb
158-4436-A-001B B Hallway near Room 114	08/02/18 8:35 AM	08/07/18 6:37 PM	18017406	Copper	1.2	1.3	ppm
158-4436-A-001B B Hallway near Room 114	08/02/18 8:35 AM	08/06/18 6:59 PM	18017406	Lead	1	15	ppb
158-4417-A-001A B Hallway near Room 111	08/02/18 8:45 AM	08/07/18 6:41 PM	18017407	Copper	1.3	1.3	ppm
158-4417-A-001A B Hallway near Room 111	08/02/18 8:45 AM	08/06/18 7:01 PM	18017407	Lead	7	15	ppb
158-4417-A-001B B Hallway near Room 111	08/02/18 8:45 AM	08/07/18 6:45 PM	18017408	Copper	1.7	1.3	ppm
158-4417-A-001B B Hallway near Room 111	08/02/18 8:45 AM	08/06/18 7:02 PM	18017408	Lead	1	15	ppb
158-4412-A-001A Kitchen Food Prep Sprayer	08/02/18 9:05 AM	08/06/18 7:04 PM	18017409	Copper	<0.1	1.3	ppm
158-4412-A-001A Kitchen Food Prep Sprayer	08/02/18 9:05 AM	08/06/18 7:04 PM	18017409	Lead	1	15	ppb
158-4412-A-001B Kitchen Food Prep Sprayer	08/02/18 9:05 AM	08/06/18 7:06 PM	18017410	Copper	<0.1	1.3	ppm
158-4412-A-001B Kitchen Food Prep Sprayer	08/02/18 9:05 AM	08/06/18 7:06 PM	18017410	Lead	1	15	ppb
158-4418-A-001A Kitchen Food Prep Sink	08/02/18 9:10 AM	08/06/18 6:04 PM	18017411	Copper	<0.1	1.3	ppm
158-4418-A-001A Kitchen Food Prep Sink	08/02/18 9:10 AM	08/06/18 6:04 PM	18017411	Lead	<1	15	ppb
158-4418-A-001B Kitchen Food Prep Sink	08/02/18 9:10 AM	08/06/18 6:06 PM	18017412	Copper	<0.1	1.3	ppm
158-4418-A-001B Kitchen Food Prep Sink	08/02/18 9:10 AM	08/06/18 6:06 PM	18017412	Lead	<1	15	ppb
158-4415-A-001A Kitchen Food Prep Sink	08/02/18 9:12 AM	08/06/18 6:08 PM	18017413	Copper	<0.1	1.3	ppm
158-4415-A-001A Kitchen Food Prep Sink	08/02/18 9:12 AM	08/06/18 6:08 PM	18017413	Lead	16	15	ppb
158-4415-A-001B Kitchen Food Prep Sink	08/02/18 9:12 AM	08/06/18 6:10 PM	18017414	Copper	<0.1	1.3	ppm
158-4415-A-001B Kitchen Food Prep Sink	08/02/18 9:12 AM	08/06/18 6:10 PM	18017414	Lead	<1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.