

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Robert Gray Middle School- Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH4405-N/A-003-A	Hallway (100)	3/28/2019	4/9/2019	A9C1075-01	Lead	1.61	0.20	15	ppb
158-CH4424-N/A-003-A	Hallway (Boiler Room)	3/28/2019	4/9/2019	A9C1075-03	Lead	1.59	0.20	15	ppb
158-CH4442-N/A-003-A	Classroom 116	3/28/2019	4/9/2019	A9C1075-05	Lead	4.22	0.20	15	ppb
158-CH4454-N/A-003-A	Classroom 119	3/28/2019	4/9/2019	A9C1075-07	Lead	11.8	0.20	15	ppb
158-CH4443-N/A-003-A	Hallway (124)	3/28/2019	4/9/2019	A9C1075-09	Lead	6.92	0.20	15	ppb
158-CH4447-N/A-003-A	Outside (G31/G24)	3/28/2019	4/9/2019	A9C1075-11	Lead	7.33	0.20	15	ppb
158-CH4441-N/A-003-A	Classroom 222	3/28/2019	4/9/2019	A9C1075-13	Lead	22.20	0.20	15	ppb
158-CH4449-N/A-003-A	Hallway (207)	3/28/2019	4/9/2019	A9C1075-15	Lead	20.20	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.