Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Robert Gray Middle School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
158-CH4449-N/A-004-A	Room G-1	5/24/2019	6/5/2019	A9E0811-32	Lead	20.40	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek