

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Rosa Parks

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
175-CH1426-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-13	Copper	0.135	0.00100	1.3	ppm
175-CH1426-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-13	Lead	1.50	0.200	15	ppb
175-CH1426-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-14	Copper	0.0662	0.00100	1.3	ppm
175-CH1426-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-14	Lead	ND	0.200	15	ppb
175-CH1429-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-11	Copper	0.120	0.00100	1.3	ppm
175-CH1429-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-11	Lead	1.31	0.200	15	ppb
175-CH1429-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-12	Copper	0.0657	0.00100	1.3	ppm
175-CH1429-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-12	Lead	ND	0.200	15	ppb
175-CH1432-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-05	Copper	0.0837	0.00100	1.3	ppm
175-CH1432-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-05	Lead	0.901	0.200	15	ppb
175-CH1432-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-06	Copper	0.0652	0.00100	1.3	ppm
175-CH1432-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-06	Lead	ND	0.200	15	ppb
175-CH1764-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-01	Copper	0.109	0.00100	1.3	ppm
175-CH1764-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-01	Lead	1.90	0.200	15	ppb
175-CH1764-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-02	Copper	0.0860	0.00100	1.3	ppm
175-CH1764-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-02	Lead	1.82	0.200	15	ppb

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

175-CH2893-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-15	Copper	0.0982	0.00100	1.3	ppm
175-CH2893-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-15	Lead	0.481	0.200	15	ppb
175-CH2893-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-16	Copper	0.0757	0.00100	1.3	ppm
175-CH2893-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-16	Lead	ND	0.200	15	ppb
175-CH2903-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-03	Copper	0.114	0.00100	1.3	ppm
175-CH2903-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-03	Lead	0.999	0.200	15	ppb
175-CH2903-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-04	Copper	0.0745	0.00100	1.3	ppm
175-CH2903-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-04	Lead	0.323	0.200	15	ppb
175-CH2906-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-07	Copper	0.177	0.00100	1.3	ppm
175-CH2906-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-07	Lead	2.67	0.200	15	ppb
175-CH2906-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-08	Copper	0.0722	0.00100	1.3	ppm
175-CH2906-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-08	Lead	0.440	0.200	15	ppb
175-CH2916-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-09	Copper	0.176	0.00100	1.3	ppm
175-CH2916-N/A-001-A	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-09	Lead	2.57	0.200	15	ppb
175-CH2916-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-10	Copper	0.0755	0.00100	1.3	ppm
175-CH2916-N/A-001-B	Hall Bubbler	3/3/2018	3/16/2018	A8C0127-10	Lead	0.241	0.200	15	ppb
175-CH2962-N/A-001-A	Kitchen Sprayer	3/3/2018	3/16/2018	A8C0127-17	Copper	0.133	0.00100	1.3	ppm
175-CH2962-N/A-001-A	Kitchen Sprayer	3/3/2018	3/16/2018	A8C0127-17	Lead	3.48	0.200	15	ppb
175-CH2962-N/A-001-B	Kitchen Sprayer	3/3/2018	3/16/2018	A8C0127-18	Copper	0.272	0.00100	1.3	ppm
175-CH2962-N/A-001-B	Kitchen Sprayer	3/3/2018	3/16/2018	A8C0127-18	Lead	0.254	0.200	15	ppb

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 2 of 2