

**Portland Public Schools
Lead Water Sampling Results
Initial Sample Data
Roosevelt**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
124-CH5550-A-001-A	Hallway Lower Theater	5/4/2019	5/6/2019	A9E0184-44	Lead	ND	0.2	15	ppb
124-CH5550-B-001-A	Hallway Lower Theater	5/4/2019	5/6/2019	A9E0184-45	Lead	ND	0.2	15	ppb
124-CH5550-C-001-A	Hallway Lower Theater	5/4/2019	5/6/2019	A9E0184-46	Lead	ND	0.2	15	ppb
124-CH5551-A-001-A	Hallway 085	5/4/2019	5/6/2019	A9E0184-42	Lead	ND	0.2	15	ppb
124-CH5551-B-001-A	Hallway 086	5/4/2019	5/6/2019	A9E0184-43	Lead	ND	0.2	15	ppb
124-CH5552-A-001-A	Hallway Gym	5/4/2019	5/6/2019	A9E0184-35	Lead	ND	0.2	15	ppb
124-CH5552-B-001-A	Hallway Gym	5/4/2019	5/6/2019	A9E0184-36	Lead	ND	0.2	15	ppb
124-CH5552-C-001-A	Hallway Gym	5/4/2019	5/6/2019	A9E0184-37	Lead	ND	0.2	15	ppb
124-CH5553-A-001-A	Girls Locker 065	5/4/2019	5/6/2019	A9E0184-32	Lead	ND	0.2	15	ppb
124-CH5553-B-001-A	Girls Locker 065	5/4/2019	5/6/2019	A9E0184-33	Lead	ND	0.2	15	ppb
124-CH5553-C-001-A	Girls Locker 065	5/4/2019	5/6/2019	A9E0184-34	Lead	ND	0.2	15	ppb
124-CH5554-A-001-A	Boys Locker 067	5/4/2019	5/6/2019	A9E0184-29	Lead	ND	0.2	15	ppb
124-CH5554-B-001-A	Boys Locker 067	5/4/2019	5/6/2019	A9E0184-30	Lead	ND	0.2	15	ppb
124-CH5554-C-001-A	Boys Locker 067	5/4/2019	5/6/2019	A9E0184-31	Lead	ND	0.2	15	ppb
124-CH5555-A-001-A	Admin Hallway	5/4/2019	5/6/2019	A9E0184-01	Lead	ND	0.2	15	ppb
124-CH5555-B-001-A	Admin Hallway	5/4/2019	5/6/2019	A9E0184-02	Lead	ND	0.2	15	ppb
124-CH5556-A-001-A	Hallway 133	5/4/2019	5/6/2019	A9E0184-04	Lead	ND	0.2	15	ppb

124-CH5556-B-001-A	Hallway 134	5/4/2019	5/6/2019	A9E0184-05	Lead	ND	0.2	15	ppb
124-CH5557-A-001-A	Hallway 175	5/4/2019	5/6/2019	A9E0184-15	Lead	ND	0.2	15	ppb
124-CH5557-B-001-A	Hallway 175	5/4/2019	5/6/2019	A9E0184-16	Lead	ND	0.2	15	ppb
124-CH5557-C-001-A	Hallway 175	5/4/2019	5/6/2019	A9E0184-17	Lead	ND	0.2	15	ppb
124-CH5558-A-001-A	Hallway 223	5/4/2019	5/6/2019	A9E0184-06	Lead	ND	0.2	15	ppb
124-CH5558-B-001-A	Hallway 223	5/4/2019	5/6/2019	A9E0184-07	Lead	ND	0.2	15	ppb
124-CH5559-A-001-A	Hallway 211	5/4/2019	5/6/2019	A9E0184-08	Lead	ND	0.2	15	ppb
124-CH5559-B-001-A	Hallway 211	5/4/2019	5/6/2019	A9E0184-09	Lead	ND	0.2	15	ppb
124-CH5561-A-001-A	Kitchen 025	5/4/2019	5/6/2019	A9E0184-40	Lead	0.214	0.2	15	ppb
124-CH5561-B-001-A	Kitchen 025	5/4/2019	5/6/2019	A9E0184-41	Lead	ND	0.2	15	ppb
124-CH5562-N/A-001-A	Teacher Planning 056	5/4/2019	5/6/2019	A9E0184-28	Lead	2.57	0.2	15	ppb
124-CH5563-N/A-001-A	Teacher Planning 013	5/4/2019	5/6/2019	A9E0184-47	Lead	1.74	0.2	15	ppb
124-CH5564-N/A-001-A	Concessions 008	5/4/2019	5/6/2019	A9E0184-48	Lead	ND	0.2	15	ppb
124-CH5565-N/A-001-A	Life Skills 059	5/4/2019	5/6/2019	A9E0184-39	Lead	0.201	0.2	15	ppb
124-CH5566-N/A-001-A	Life Skills 057	5/4/2019	5/6/2019	A9E0184-38	Lead	0.269	0.2	15	ppb
124-CH5569-N/A-001-A	Teacher Planning 104	5/4/2019	5/6/2019	A9E0184-23	Lead	0.585	0.2	15	ppb
124-CH5570-N/A-001-A	Teacher Planning 121	5/4/2019	5/6/2019	A9E0184-24	Lead	0.345	0.2	15	ppb
124-CH5571-N/A-001-A	Headstart Kitchen	5/4/2019	5/6/2019	A9E0184-03	Lead	0.535	0.2	15	ppb
124-CH5573-N/A-001-A	Family Room 105F	5/4/2019	5/6/2019	A9E0184-22	Lead	0.263	0.2	15	ppb
124-CH5574-N/A-001-A	Teacher Planning 158	5/4/2019	5/6/2019	A9E0184-14	Lead	0.919	0.2	15	ppb
124-CH5575-N/A-001-A	Teacher Planning 207	5/4/2019	5/6/2019	A9E0184-10	Lead	0.689	0.2	15	ppb
124-CH5576-N/A-001-A	Teacher Planning 226	5/4/2019	5/6/2019	A9E0184-20	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level is 15.0 ppb

Reviewed by: PBS Engineering and Environmental

124-CH5579-N/A-001-A	Teacher Planning 260	5/4/2019	5/6/2019	A9E0184-12	Lead	2.98	0.2	15	ppb
124-CH5580-N/A-001-A	Teacher Planning 271	5/4/2019	5/6/2019	A9E0184-11	Lead	0.314	0.2	15	ppb
124-CH5581-A-001-A	Hallway 030	5/4/2019	5/6/2019	A9E0184-25	Lead	ND	0.2	15	ppb
124-CH5581-B-001-A	Hallway 030	5/4/2019	5/6/2019	A9E0184-26	Lead	ND	0.2	15	ppb
124-CH5582-N/A-001-A	Hallway 151	5/4/2019	5/6/2019	A9E0184-13	Lead	ND	0.2	15	ppb
124-CH5583-N/A-001-A	Hallway 251	5/4/2019	5/6/2019	A9E0184-18	Lead	ND	0.2	15	ppb
124-CH5584-N/A-001-A	Hallway 271	5/4/2019	5/6/2019	A9E0184-19	Lead	ND	0.2	15	ppb
124-CH5585-N/A-001-A	Hallway 031	5/4/2019	5/6/2019	A9E0184-27	Lead	ND	0.2	15	ppb
124-CH5586-N/A-001-A	Hallway 191	5/4/2019	5/6/2019	A9E0184-21	Lead	ND	0.2	15	ppb