

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Roseway Heights Middle School**

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
254-4673-NA-001-A	Drinking Fountain (Stainless) - Near 190	11/9/2018	11/13/2018	A8K0327-01	Copper	0.598	0.00200	1.3	ppm
254-4673-NA-001-A	Drinking Fountain (Stainless) - Near 190	11/9/2018	11/13/2018	A8K0327-01	Lead	24.3	0.200	15	ppb
254-4673-NA-001-B	Drinking Fountain (Stainless) - Near 190	11/9/2018	11/13/2018	A8K0327-02	Copper	0.205	0.00200	1.3	ppm
254-4673-NA-001-B	Drinking Fountain (Stainless) - Near 190	11/9/2018	11/13/2018	A8K0327-02	Lead	2.56	0.200	15	ppb
254-4677-NA-001-A	Bubbler - Near 222	11/9/2018	11/13/2018	A8K0327-03	Copper	0.452	0.00200	1.3	ppm
254-4677-NA-001-A	Bubbler - Near 222	11/9/2018	11/13/2018	A8K0327-03	Lead	4.14	0.200	15	ppb
254-4677-NA-001-B	Bubbler - Near 222	11/9/2018	11/13/2018	A8K0327-04	Copper	0.360	0.00200	1.3	ppm
254-4677-NA-001-B	Bubbler - Near 222	11/9/2018	11/13/2018	A8K0327-04	Lead	0.762	0.200	15	ppb
254-4688-NA-001-A	Sink Bubbler - Classroom 214	11/9/2018	11/13/2018	A8K0327-05	Copper	0.571	0.00200	1.3	ppm
254-4688-NA-001-A	Sink Bubbler - Classroom 214	11/9/2018	11/13/2018	A8K0327-05	Lead	28.8	0.200	15	ppb
254-4688-NA-001-B	Sink Bubbler - Classroom 214	11/9/2018	11/13/2018	A8K0327-06	Copper	0.514	0.00200	1.3	ppm
254-4688-NA-001-B	Sink Bubbler - Classroom 214	11/9/2018	11/13/2018	A8K0327-06	Lead	4.84	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.