

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Roseway Heights - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
254-CH4725-N/A-003-A	Classroom 129	3/27/2019	4/10/2019	A9C1084-01	Lead	5.63	0.20	15	ppb
254-CH4673-N/A-003-A	Hallway 190	3/27/2019	4/10/2019	A9C1084-03	Lead	11.3	0.20	15	ppb
254-CH4676-N/A-003-A	Classroom 184	3/27/2019	4/10/2019	A9C1084-05	Lead	4.25	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15 ppb