

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Sacajawea Head Start

Sample Identification #		Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
368-2211-N/A-001-A		Sink Bubblers - Classroom 103	8/10/2018	8/22/2018	A8H0308-01RE2	Copper	0.0764	0.00200	1.3	ppm
368-2211-N/A-001-A		Sink Bubblers - Classroom 103	8/10/2018	8/22/2018	A8H0308-01RE2	Lead	15.6	0.200	15	ppb
368-2211-N/A-001-B		Sink Bubblers - Classroom 103	8/10/2018	8/22/2018	A8H0308-02RE2	Copper	0.106	0.00200	1.3	ppm
368-2211-N/A-001-B		Sink Bubblers - Classroom 103	8/10/2018	8/22/2018	A8H0308-02RE2	Lead	59.7	0.200	15	ppb
368-2212-N/A-001-A		Sink Bubblers - Classroom 104	8/10/2018	8/22/2018	A8H0308-03RE2	Copper	0.0532	0.00200	1.3	ppm
368-2212-N/A-001-A		Sink Bubblers - Classroom 104	8/10/2018	8/22/2018	A8H0308-03RE2	Lead	21.8	0.200	15	ppb
368-2212-N/A-001-B		Sink Bubblers - Classroom 104	8/10/2018	8/22/2018	A8H0308-04RE2	Copper	0.0539	0.00200	1.3	ppm
368-2212-N/A-001-B		Sink Bubblers - Classroom 104	8/10/2018	8/22/2018	A8H0308-04RE2	Lead	40.2	0.200	15	ppb
368-2213-N/A-001-A		Sink Bubblers - Classroom 105	8/10/2018	8/22/2018	A8H0308-05RE2	Copper	0.0276	0.00200	1.3	ppm
368-2213-N/A-001-A		Sink Bubblers - Classroom 105	8/10/2018	8/22/2018	A8H0308-05RE2	Lead	7.00	0.200	15	ppb
368-2213-N/A-001-B		Sink Bubblers - Classroom 105	8/10/2018	8/22/2018	A8H0308-06RE2	Copper	0.0212	0.00200	1.3	ppm
368-2213-N/A-001-B		Sink Bubblers - Classroom 105	8/10/2018	8/22/2018	A8H0308-06RE2	Lead	6.18	0.200	15	ppb
368-2214-N/A-001-A		Sink Bubblers - Classroom 106	8/10/2018	8/22/2018	A8H0308-07RE2	Copper	0.0252	0.00200	1.3	ppm
368-2214-N/A-001-A		Sink Bubblers - Classroom 106	8/10/2018	8/22/2018	A8H0308-07RE2	Lead	26.5	0.200	15	ppb
368-2214-N/A-001-B		Sink Bubblers - Classroom 106	8/10/2018	8/22/2018	A8H0308-08RE2	Copper	0.0177	0.00200	1.3	ppm
368-2214-N/A-001-B		Sink Bubblers - Classroom 106	8/10/2018	8/22/2018	A8H0308-08RE2	Lead	7.65	0.200	15	ppb
368-2218-N/A-001-A		Drinking Fountain (Metal) - Hallway by Kitchen	8/10/2018	8/22/2018	A8H0308-09RE1	Copper	0.144	0.00200	1.3	ppm
368-2218-N/A-001-A		Drinking Fountain (Metal) - Hallway by Kitchen	8/10/2018	8/22/2018	A8H0308-09RE1	Lead	12.1	0.200	15	ppb
368-2218-N/A-001-B		Drinking Fountain (Metal) - Hallway by Kitchen	8/10/2018	8/22/2018	A8H0308-10RE1	Copper	0.137	0.00200	1.3	ppm
368-2218-N/A-001-B		Drinking Fountain (Metal) - Hallway by Kitchen	8/10/2018	8/22/2018	A8H0308-10RE1	Lead	8.90	0.200	15	ppb
368-2216-A-001-A		Food Prep Sprayer - Kitchen	8/10/2018	8/22/2018	A8H0308-11RE1	Copper	0.103	0.00200	1.3	ppm
368-2216-A-001-A		Food Prep Sprayer - Kitchen	8/10/2018	8/22/2018	A8H0308-11RE1	Lead	1.43	0.200	15	ppb
368-2216-A-001-B		Food Prep Sprayer - Kitchen	8/10/2018	8/22/2018	A8H0308-12RE1	Copper	0.0202	0.00200	1.3	ppm

368-2216-A-001-B	Food Prep Sprayer - Kitchen	8/10/2018	8/22/2018	A8H0308-12RE1	Lead	1.50	0.200	15	ppb
368-2216-B-001-A	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-13RE1	Copper	0.527	0.00200	1.3	ppm
368-2216-B-001-A	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-13RE1	Lead	3.51	0.200	15	ppb
368-2216-B-001-B	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-14RE1	Copper	0.0208	0.00200	1.3	ppm
368-2216-B-001-B	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-14RE1	Lead	1.24	0.200	15	ppb
368-2217-N/A-001-A	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-15RE1	Copper	0.188	0.00200	1.3	ppm
368-2217-N/A-001-A	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-15RE1	Lead	6.94	0.200	15	ppb
368-2217-N/A-001-B	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-16RE1	Copper	0.0200	0.00200	1.3	ppm
368-2217-N/A-001-B	Food Prep Faucet - Kitchen	8/10/2018	8/22/2018	A8H0308-16RE1	Lead	0.825	0.200	15	ppb
368-2219-N/A-001-A	Sink Bubbler - Classroom 108	8/10/2018	8/22/2018	A8H0308-17RE1	Copper	0.0348	0.00200	1.3	ppm
368-2219-N/A-001-A	Sink Bubbler - Classroom 108	8/10/2018	8/22/2018	A8H0308-17RE1	Lead	25.8	0.200	15	ppb
368-2219-N/A-001-B	Sink Bubbler - Classroom 108	8/10/2018	8/22/2018	A8H0308-18RE1	Copper	0.0145	0.00200	1.3	ppm
368-2219-N/A-001-B	Sink Bubbler - Classroom 108	8/10/2018	8/22/2018	A8H0308-18RE1	Lead	7.31	0.200	15	ppb
368-2220-N/A-001-A	Sink Faucet - Classroom 109	8/10/2018	8/22/2018	A8H0308-19RE1	Copper	0.0997	0.00200	1.3	ppm
368-2220-N/A-001-A	Sink Faucet - Classroom 109	8/10/2018	8/22/2018	A8H0308-19RE1	Lead	4.56	0.200	15	ppb
368-2220-N/A-001-B	Sink Faucet - Classroom 109	8/10/2018	8/22/2018	A8H0308-20RE1	Copper	0.0111	0.00200	1.3	ppm
368-2220-N/A-001-B	Sink Faucet - Classroom 109	8/10/2018	8/22/2018	A8H0308-20RE1	Lead	1.62	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.