

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Scott Elementary - 2nd Site Visit

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
282-2193-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 207	8/16/2018	8/25/2018	A8H0454-01	Copper	0.00501	0.00200	1.3	ppm
282-2193-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 207	8/16/2018	8/25/2018	A8H0454-01	Lead	8.20	0.200	15	ppb
282-2193-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 207	8/16/2018	8/25/2018	A8H0454-02	Copper	0.00458	0.00200	1.3	ppm
282-2193-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 207	8/16/2018	8/25/2018	A8H0454-02	Lead	4.83	0.200	15	ppb
282-2195-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 205	8/16/2018	8/25/2018	A8H0454-03	Copper	0.0696	0.00200	1.3	ppm
282-2195-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 205	8/16/2018	8/25/2018	A8H0454-03	Lead	8.33	0.200	15	ppb
282-2195-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 205	8/16/2018	8/25/2018	A8H0454-04	Copper	0.373	0.00200	1.3	ppm
282-2195-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 205	8/16/2018	8/25/2018	A8H0454-04	Lead	28.7	0.200	15	ppb
282-2197-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 203	8/16/2018	8/25/2018	A8H0454-05	Copper	0.0160	0.00200	1.3	ppm
282-2197-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 203	8/16/2018	8/25/2018	A8H0454-05	Lead	2.06	0.200	15	ppb
282-2197-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 203	8/16/2018	8/25/2018	A8H0454-06	Copper	0.0126	0.00200	1.3	ppm
282-2197-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 203	8/16/2018	8/25/2018	A8H0454-06	Lead	1.18	0.200	15	ppb
282-2200-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 201	8/16/2018	8/25/2018	A8H0454-07	Copper	0.0108	0.00200	1.3	ppm
282-2200-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 201	8/16/2018	8/25/2018	A8H0454-07	Lead	7.47	0.200	15	ppb
282-2200-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 201	8/16/2018	8/25/2018	A8H0454-08	Copper	0.0107	0.00200	1.3	ppm
282-2200-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 201	8/16/2018	8/25/2018	A8H0454-08	Lead	5.83	0.200	15	ppb
282-2201-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 202	8/16/2018	8/25/2018	A8H0454-09	Copper	0.0281	0.00200	1.3	ppm
282-2201-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 202	8/16/2018	8/25/2018	A8H0454-09	Lead	11.3	0.200	15	ppb
282-2201-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 202	8/16/2018	8/25/2018	A8H0454-10	Copper	0.0151	0.00200	1.3	ppm
282-2201-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 202	8/16/2018	8/25/2018	A8H0454-10	Lead	2.81	0.200	15	ppb
282-2198-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 204	8/16/2018	8/25/2018	A8H0454-11	Copper	0.0141	0.00200	1.3	ppm
282-2198-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 204	8/16/2018	8/25/2018	A8H0454-11	Lead	5.27	0.200	15	ppb
282-2198-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 204	8/16/2018	8/25/2018	A8H0454-12	Copper	0.0113	0.00200	1.3	ppm

282-2198-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 204	8/16/2018	8/25/2018	A8H0454-12	Lead	3.35	0.200	15	ppb
282-2196-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 206	8/16/2018	8/25/2018	A8H0454-13	Copper	0.00611	0.00200	1.3	ppm
282-2196-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 206	8/16/2018	8/25/2018	A8H0454-13	Lead	7.72	0.200	15	ppb
282-2196-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 206	8/16/2018	8/25/2018	A8H0454-14	Copper	0.00740	0.00200	1.3	ppm
282-2196-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 206	8/16/2018	8/25/2018	A8H0454-14	Lead	8.31	0.200	15	ppb
282-2194-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 208	8/16/2018	8/25/2018	A8H0454-15	Copper	0.203	0.00200	1.3	ppm
282-2194-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 208	8/16/2018	8/25/2018	A8H0454-15	Lead	21.3	0.200	15	ppb
282-2194-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 208	8/16/2018	8/25/2018	A8H0454-16	Copper	0.0502	0.00200	1.3	ppm
282-2194-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 208	8/16/2018	8/25/2018	A8H0454-16	Lead	7.93	0.200	15	ppb
282-2176-N/A-001-A	Bubbler - Gym North Wall	8/16/2018	8/25/2018	A8H0454-17	Copper	0.0145	0.00200	1.3	ppm
282-2176-N/A-001-A	Bubbler - Gym North Wall	8/16/2018	8/25/2018	A8H0454-17	Lead	15.7	0.200	15	ppb
282-2176-N/A-001-B	Bubbler - Gym North Wall	8/16/2018	8/25/2018	A8H0454-18	Copper	0.00237	0.00200	1.3	ppm
282-2176-N/A-001-B	Bubbler - Gym North Wall	8/16/2018	8/25/2018	A8H0454-18	Lead	2.81	0.200	15	ppb
282-2190-N/A-001-A	Sink (Food Prep) - Lounge 300	8/16/2018	8/25/2018	A8H0454-19	Copper	0.0722	0.00200	1.3	ppm
282-2190-N/A-001-A	Sink (Food Prep) - Lounge 300	8/16/2018	8/25/2018	A8H0454-19	Lead	4.61	0.200	15	ppb
282-2190-N/A-001-B	Sink (Food Prep) - Lounge 300	8/16/2018	8/25/2018	A8H0454-20	Copper	0.0160	0.00200	1.3	ppm
282-2190-N/A-001-B	Sink (Food Prep) - Lounge 300	8/16/2018	8/25/2018	A8H0454-20	Lead	2.00	0.200	15	ppb
282-2189-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 302	8/16/2018	8/25/2018	A8H0454-21	Copper	0.0221	0.00200	1.3	ppm
282-2189-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 302	8/16/2018	8/25/2018	A8H0454-21	Lead	14.8	0.200	15	ppb
282-2189-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 302	8/16/2018	8/25/2018	A8H0454-22	Copper	0.0362	0.00200	1.3	ppm
282-2189-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 302	8/16/2018	8/25/2018	A8H0454-22	Lead	30.4	0.200	15	ppb
282-2188-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 304	8/16/2018	8/25/2018	A8H0454-23	Copper	0.00847	0.00200	1.3	ppm
282-2188-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 304	8/16/2018	8/25/2018	A8H0454-23	Lead	5.52	0.200	15	ppb
282-2188-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 304	8/16/2018	8/25/2018	A8H0454-24	Copper	0.00952	0.00200	1.3	ppm
282-2188-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 304	8/16/2018	8/25/2018	A8H0454-24	Lead	1.69	0.200	15	ppb
282-2187-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 306	8/16/2018	8/25/2018	A8H0454-25	Copper	0.0556	0.00200	1.3	ppm
282-2187-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 306	8/16/2018	8/25/2018	A8H0454-25	Lead	12.9	0.200	15	ppb
282-2187-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 306	8/16/2018	8/25/2018	A8H0454-26	Copper	0.00536	0.00200	1.3	ppm

282-2187-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 306	8/16/2018	8/25/2018	A8H0454-26	Lead	0.961	0.200	15	ppb
282-2185-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 307	8/16/2018	8/25/2018	A8H0454-27	Copper	0.0144	0.00200	1.3	ppm
282-2185-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 307	8/16/2018	8/25/2018	A8H0454-27	Lead	8.64	0.200	15	ppb
282-2185-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 307	8/16/2018	8/25/2018	A8H0454-28	Copper	0.00458	0.00200	1.3	ppm
282-2185-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 307	8/16/2018	8/25/2018	A8H0454-28	Lead	0.854	0.200	15	ppb
282-2184-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 305	8/16/2018	8/25/2018	A8H0454-29	Copper	0.0511	0.00200	1.3	ppm
282-2184-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 305	8/16/2018	8/25/2018	A8H0454-29	Lead	16.0	0.200	15	ppb
282-2184-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 305	8/16/2018	8/25/2018	A8H0454-30	Copper	0.0314	0.00200	1.3	ppm
282-2184-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 305	8/16/2018	8/25/2018	A8H0454-30	Lead	2.53	0.200	15	ppb
282-2183-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 303	8/16/2018	8/25/2018	A8H0454-31	Copper	0.105	0.00200	1.3	ppm
282-2183-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 303	8/16/2018	8/25/2018	A8H0454-31	Lead	20.5	0.200	15	ppb
282-2183-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 303	8/16/2018	8/25/2018	A8H0454-32	Copper	0.0259	0.00200	1.3	ppm
282-2183-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 303	8/16/2018	8/25/2018	A8H0454-32	Lead	3.92	0.200	15	ppb
282-2182-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 301	8/16/2018	8/25/2018	A8H0454-33	Copper	0.0107	0.00200	1.3	ppm
282-2182-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 301	8/16/2018	8/25/2018	A8H0454-33	Lead	12.3	0.200	15	ppb
282-2182-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 301	8/16/2018	8/25/2018	A8H0454-34	Copper	0.0134	0.00200	1.3	ppm
282-2182-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 301	8/16/2018	8/25/2018	A8H0454-34	Lead	3.16	0.200	15	ppb
282-2181-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 402	8/16/2018	8/25/2018	A8H0454-35	Copper	0.0686	0.00200	1.3	ppm
282-2181-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 402	8/16/2018	8/25/2018	A8H0454-35	Lead	22.2	0.200	15	ppb
282-2181-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 402	8/16/2018	8/25/2018	A8H0454-36	Copper	0.109	0.00200	1.3	ppm
282-2181-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 402	8/16/2018	8/25/2018	A8H0454-36	Lead	36.9	0.200	15	ppb
282-2208-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 501	8/16/2018	8/25/2018	A8H0454-37	Copper	0.0246	0.00200	1.3	ppm
282-2208-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 501	8/16/2018	8/25/2018	A8H0454-37	Lead	4.93	0.200	15	ppb
282-2208-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 501	8/16/2018	8/25/2018	A8H0454-38	Copper	0.0494	0.00200	1.3	ppm
282-2208-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 501	8/16/2018	8/25/2018	A8H0454-38	Lead	2.55	0.200	15	ppb
282-2204-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 104	8/16/2018	8/25/2018	A8H0454-39	Copper	0.0232	0.00200	1.3	ppm
282-2204-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 104	8/16/2018	8/25/2018	A8H0454-39	Lead	10.7	0.200	15	ppb
282-2204-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 104	8/16/2018	8/25/2018	A8H0454-40	Copper	0.0517	0.00200	1.3	ppm

282-2204-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 104	8/16/2018	8/25/2018	A8H0454-40	Lead	17.0	0.200	15	ppb
282-2205-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 103	8/16/2018	8/25/2018	A8H0454-41	Copper	0.0209	0.00200	1.3	ppm
282-2205-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 103	8/16/2018	8/25/2018	A8H0454-41	Lead	15.1	0.200	15	ppb
282-2205-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 103	8/16/2018	8/25/2018	A8H0454-42	Copper	0.0323	0.00200	1.3	ppm
282-2205-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 103	8/16/2018	8/25/2018	A8H0454-42	Lead	32.3	0.200	15	ppb
282-2203-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/16/2018	8/25/2018	A8H0454-43	Copper	0.0494	0.00200	1.3	ppm
282-2203-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/16/2018	8/25/2018	A8H0454-43	Lead	1.96	0.200	15	ppb
282-2203-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/16/2018	8/25/2018	A8H0454-44	Copper	0.0146	0.00200	1.3	ppm
282-2203-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/16/2018	8/25/2018	A8H0454-44	Lead	0.672	0.200	15	ppb
282-2202-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 106	8/16/2018	8/25/2018	A8H0454-45	Copper	0.00904	0.00200	1.3	ppm
282-2202-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 106	8/16/2018	8/25/2018	A8H0454-45	Lead	2.84	0.200	15	ppb
282-2202-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 106	8/16/2018	8/25/2018	A8H0454-46	Copper	0.0147	0.00200	1.3	ppm
282-2202-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 106	8/16/2018	8/25/2018	A8H0454-46	Lead	7.73	0.200	15	ppb
282-2206-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 101	8/16/2018	8/25/2018	A8H0454-47	Copper	0.00804	0.00200	1.3	ppm
282-2206-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 101	8/16/2018	8/25/2018	A8H0454-47	Lead	14.8	0.200	15	ppb
282-2206-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 101	8/16/2018	8/25/2018	A8H0454-48	Copper	0.00533	0.00200	1.3	ppm
282-2206-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 101	8/16/2018	8/25/2018	A8H0454-48	Lead	4.66	0.200	15	ppb
282-2207-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 102	8/16/2018	8/25/2018	A8H0454-49	Copper	0.00610	0.00200	1.3	ppm
282-2207-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 102	8/16/2018	8/25/2018	A8H0454-49	Lead	10.7	0.200	15	ppb
282-2207-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 102	8/16/2018	8/25/2018	A8H0454-50	Copper	0.00419	0.00200	1.3	ppm
282-2207-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 102	8/16/2018	8/25/2018	A8H0454-50	Lead	3.68	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.