

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Scott Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
282-CH2176-N/A-003-A	Gym	4/30/2019	5/14/2019	A9E0104-01	Lead	4.16	0.20	15	ppb
282-CH2177-N/A-003-A	Gym	4/30/2019	5/14/2019	A9E0104-02	Lead	6.45	0.20	15	ppb
282-CH2179-N/A-003-A	Hallway (403)	4/30/2019	5/14/2019	A9E0104-03	Lead	12.2	0.20	15	ppb
282-CH2186-N/A-003-A	Hallway (305)	4/30/2019	5/14/2019	A9E0104-04	Lead	5.4	0.20	15	ppb