

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Sellwood

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-CH1296-A-001-A	By 104	8/16/2018	8/22/2018	1808834-01A	Copper	0.0897	0.0000259	1.3	ppm
283-CH1296-A-001-A	By 104	8/16/2018	8/22/2018	1808834-01A	Lead	19.7	0.00000523	15	ppb
283-CH1296-A-001-B	By 104	8/16/2018	8/22/2018	1808834-02A	Copper	0.0102	0.0000259	1.3	ppm
283-CH1296-A-001-B	By 104	8/16/2018	8/22/2018	1808834-02A	Lead	4.13	0.00000523	15	ppb
283-CH1296-B-001-A	By 104	8/16/2018	8/22/2018	1808834-03A	Copper	0.0605	0.0000259	1.3	ppm
283-CH1296-B-001-A	By 104	8/16/2018	8/22/2018	1808834-03A	Lead	7.05	0.00000523	15	ppb
283-CH1296-B-001-B	By 104	8/16/2018	8/22/2018	1808834-04A	Copper	0.00785	0.0000259	1.3	ppm
283-CH1296-B-001-B	By 104	8/16/2018	8/22/2018	1808834-04A	Lead	1.49	0.00000523	15	ppb
283-CH1294-N/A-001-A	Kitchen	8/16/2018	8/22/2018	1808834-05A	Copper	0.138	0.0000259	1.3	ppm
283-CH1294-N/A-001-A	Kitchen	8/16/2018	8/22/2018	1808834-05A	Lead	7.44	0.00000523	15	ppb
283-CH1294-N/A-001-B	Kitchen	8/16/2018	8/22/2018	1808834-06A	Copper	0.175	0.0000259	1.3	ppm
283-CH1294-N/A-001-B	Kitchen	8/16/2018	8/22/2018	1808834-06A	Lead	1.46	0.00000523	15	ppb
283-CH1285-N/A-001-A	Kitchen	8/16/2018	8/22/2018	1808834-07A	Copper	0.133	0.0000259	1.3	ppm
283-CH1285-N/A-001-A	Kitchen	8/16/2018	8/22/2018	1808834-07A	Lead	1.72	0.00000523	15	ppb
283-CH1285-N/A-001-B	Kitchen	8/16/2018	8/22/2018	1808834-08A	Copper	0.154	0.0000259	1.3	ppm
283-CH1285-N/A-001-B	Kitchen	8/16/2018	8/22/2018	1808834-08A	Lead	2.18	0.00000523	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 1 of 3

283-CH1288-A-001-A	Near CR 121	8/16/2018	8/22/2018	1808834-09A	Copper	0.0442	0.0000259	1.3	ppm
283-CH1288-A-001-A	Near CR 121	8/16/2018	8/22/2018	1808834-09A	Lead	8.06	0.00000523	15	ppm
283-CH1288-A-001-B	Near CR 121	8/16/2018	8/22/2018	1808834-10A	Copper	0.0249	0.0000259	1.3	ppm
283-CH1288-A-001-B	Near CR 121	8/16/2018	8/22/2018	1808834-10A	Lead	7.38	0.00000523	15	ppb
283-CH1288-B-001-A	Near CR 121	8/16/2018	8/22/2018	1808834-11A	Copper	0.0523	0.0000259	1.3	ppm
283-CH1288-B-001-A	Near CR 121	8/16/2018	8/22/2018	1808834-11A	Lead	6.62	0.00000523	15	ppb
283-CH1288-B-001-B	Near CR 121	8/16/2018	8/22/2018	1808834-12A	Copper	0.0235	0.0000259	1.3	ppm
283-CH1288-B-001-B	Near CR 121	8/16/2018	8/22/2018	1808834-12A	Lead	4.37	0.00000523	15	ppb
283-CH1246-N/A-001-A	Near RR 136	8/16/2018	8/23/2018	1808834-13A	Copper	1.13	0.000259	1.3	ppm
283-CH1246-N/A-001-A	Near RR 136	8/16/2018	8/23/2018	1808834-13A	Lead	21.2	0.00000523	15	ppb
283-CH1246-N/A-001-B	Near RR 136	8/16/2018	8/22/2018	1808834-14A	Copper	0.644	0.0000259	1.3	ppm
283-CH1246-N/A-001-B	Near RR 136	8/16/2018	8/22/2018	1808834-14A	Lead	6.51	0.00000523	15	ppb
283-CH1231-N/A-001-A	Near RR 136	8/16/2018	8/23/2018	1808834-15A	Copper	1.52	0.000259	1.3	ppm
283-CH1231-N/A-001-A	Near RR 136	8/16/2018	8/22/2018	1808834-15A	Lead	6.04	0.00000523	15	ppb
283-CH1231-N/A-001-B	Near RR 136	8/16/2018	8/23/2018	1808834-16A	Copper	0.845	0.000259	1.3	ppm
283-CH1231-N/A-001-B	Near RR 136	8/16/2018	8/22/2018	1808834-16A	Lead	1.72	0.00000523	15	ppb
283-CH1249-A-001-A	Near RM 222	8/16/2018	8/22/2018	1808834-17A	Copper	0.0614	0.0000259	1.3	ppm
283-CH1249-A-001-A	Near RM 222	8/16/2018	8/22/2018	1808834-17A	Lead	17.3	0.00000523	15	ppb
283-CH1249-A-001-B	Near RM 222	8/16/2018	8/22/2018	1808834-18A	Copper	0.0132	0.0000259	1.3	ppm
283-CH1249-A-001-B	Near RM 222	8/16/2018	8/22/2018	1808834-18A	Lead	4.07	0.00000523	15	ppb

Analyzed by:

283-CH1249-B-001-A	Near RM 222	8/16/2018	8/22/2018	1808834-19A	Copper	0.0166	0.0000259	1.3	ppm
283-CH1249-B-001-A	Near RM 222	8/16/2018	8/22/2018	1808834-19A	Lead	4.76	0.00000523	15	ppb
283-CH1249-B-001-B	Near RM 222	8/16/2018	8/22/2018	1808834-20A	Copper	0.0103	0.0000259	1.3	ppm
283-CH1249-B-001-B	Near RM 222	8/16/2018	8/22/2018	1808834-20A	Lead	3.16	0.00000523	15	ppb
283-CH1247-A-001-A	Near CR 309	8/16/2018	8/21/2018	1808834-21A	Copper	0.0388	0.0000259	1.3	ppm
283-CH1247-A-001-A	Near CR 309	8/16/2018	8/21/2018	1808834-21A	Lead	14.3	0.00000523	15	ppb
283-CH1247-A-001-B	Near CR 309	8/16/2018	8/21/2018	1808834-22A	Copper	0.00642	0.0000259	1.3	ppm
283-CH1247-A-001-B	Near CR 309	8/16/2018	8/21/2018	1808834-22A	Lead	11.7	0.00000523	15	ppb
283-CH1247-B-001-A	Near CR 309	8/16/2018	8/21/2018	1808834-23A	Copper	0.0241	0.0000259	1.3	ppm
283-CH1247-B-001-A	Near CR 309	8/16/2018	8/21/2018	1808834-23A	Lead	17.6	0.00000523	15	ppb
283-CH1247-B-001-B	Near CR 309	8/16/2018	8/21/2018	1808834-24A	Copper	0.00581	0.0000259	1.3	ppm
283-CH1247-B-001-B	Near CR 309	8/16/2018	8/21/2018	1808834-24A	Lead	0.89	0.00000523	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: