

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Sellwood

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-CH1246-N/A-002-A	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-03	Copper	0.261	0.00200	1.3	ppm
283-CH1246-N/A-002-A	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-03	Lead	6.67	0.200	15	ppb
283-CH1246-N/A-002-B	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-04	Copper	0.0530	0.00200	1.3	ppm
283-CH1246-N/A-002-B	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-04	Lead	1.84	0.200	15	ppb
283-CH1431-N/A-002-A	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-01	Copper	0.500	0.00200	1.3	ppm
283-CH1431-N/A-002-A	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-01	Lead	5.70	0.200	15	ppb
283-CH1431-N/A-002-B	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-02	Copper	0.0785	0.00200	1.3	ppm
283-CH1431-N/A-002-B	Hall Bubbler	11/1/2018	11/5/2018	A8K0052-02	Lead	1.42	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 1 of 1