

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sellwood Middle School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-CH1248-A-003-A	Hallway (207)	4/4/2019	4/16/2019	A9D0368-01	Lead	3.95	0.20	15	ppb
283-CH1248-B-003-A	Hallway (207)	4/4/2019	4/16/2019	A9D0368-03	Lead	5.05	0.20	15	ppb
283-CH1296-A-003-A	Hallway (105)	4/4/2019	4/16/2019	A9D0368-05	Lead	3.01	0.20	15	ppb
283-CH1297-N/A-003-A	Cafeteria	4/4/2019	4/16/2019	A9D0368-07	Lead	2.62	0.20	15	ppb
283-CH1247-A-003-A	Hallway (307)	4/4/2019	4/16/2019	A9D0368-09	Lead	2.79	0.20	15	ppb
283-CH1247-B-003-A	Hallway (307)	4/4/2019	4/16/2019	A9D0368-11	Lead	5.26	0.20	15	ppb
283-CH1245-N/A-003-A	Gym	4/4/2019	4/16/2019	A9D0368-13	Lead	2.15	0.20	15	ppb