

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sellwood Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
283-CH1288-A-005-A	Hallway (121)	6/6/2019	6/7/2019	A9F0229-01	Lead	1.09	0.20	15	ppb
283-CH1288-B-005-A	Hallway (121)	6/6/2019	6/7/2019	A9F0229-02	Lead	6.68	0.20	15	ppb
283-CH1296-A-005-A	Hallway (105)	6/6/2019	6/7/2019	A9F0229-03	Lead	3.57	0.20	15	ppb
283-CH1296-B-005-A	Hallway (105)	6/6/2019	6/7/2019	A9F0229-04	Lead	4.11	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb