

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sitton Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
184-CH2725-N/A-003-A	Classroom 4	4/2/2019	4/16/2019	A9D0332-01	Lead	10.6	0.20	15	ppb
184-CH2704-N/A-003-A	Classroom 1	4/2/2019	4/16/2019	A9D0332-03	Lead	16.30	0.20	15	ppb
184-CH2728-N/A-003-A	Classroom 20	4/2/2019	4/16/2019	A9D0332-05	Lead	2.24	0.20	15	ppb
184-CH2709-N/A-003-A	Cafeteria	4/2/2019	4/16/2019	A9D0332-07	Lead	53.30	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.