

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Skyline School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
186-CH1995-N/A-003-A	Outside (Near Stage)	4/16/2019	4/26/2019	A9D0751-01	Lead	5.33	0.20	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek