

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Stephenson

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
190-CH2009-N/A-001-A	Kitchen Prep Sink/Initial	7/30/2018	8/6/2018	1808203-01A	Copper	0.260	0.0000251	1.3	ppm
190-CH2009-N/A-001-A	Kitchen Prep Sink/Initial	7/30/2018	8/6/2018	1808203-01A	Lead	5.67	0.00508	15	ppb
190-CH2009-N/A-001-B	Kitchen Prep Sink/2nd	7/30/2018	8/6/2018	1808203-02A	Copper	0.343	0.0000251	1.3	ppm
190-CH2009-N/A-001-B	Kitchen Prep Sink/2nd	7/30/2018	8/6/2018	1808203-02A	Lead	2.29	0.00508	15	ppb