

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Stephenson Elementary**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
190-CH2006-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-07	Copper	0.0230	0.00200	1.3	ppm
190-CH2006-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-07	Lead	10.5	0.200	15	ppb
190-CH2006-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-08	Copper	0.00670	0.00200	1.3	ppm
190-CH2006-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-08	Lead	2.07	0.200	15	ppb
190-CH2007-N/A-001-A	Cafeteria Bubblers	8/29/2018	9/6/2018	A8H0855-03	Copper	0.0394	0.00200	1.3	ppm
190-CH2007-N/A-001-A	Cafeteria Bubblers	8/29/2018	9/6/2018	A8H0855-03	Lead	15.4	0.200	15	ppb
190-CH2007-N/A-001-B	Cafeteria Bubblers	8/29/2018	9/6/2018	A8H0855-04	Copper	0.00285	0.00200	1.3	ppm
190-CH2007-N/A-001-B	Cafeteria Bubblers	8/29/2018	9/6/2018	A8H0855-04	Lead	9.60	0.200	15	ppb
190-CH2013-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-01	Copper	0.0223	0.00200	1.3	ppm
190-CH2013-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-01	Lead	8.59	0.200	15	ppb
190-CH2013-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-02	Copper	0.00611	0.00200	1.3	ppm
190-CH2013-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-02	Lead	1.25	0.200	15	ppb
190-CH2016-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-05	Copper	0.0216	0.00200	1.3	ppm
190-CH2016-N/A-001-A	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-05	Lead	16.0	0.200	15	ppb
190-CH2016-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-06	Copper	0.0177	0.00200	1.3	ppm
190-CH2016-N/A-001-B	Hallway Bubblers	8/29/2018	9/6/2018	A8H0855-06	Lead	5.42	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 1