Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Stephenson

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
190-CH1892-N/A-003-A	Room 121	11/7/2018	11/12/2018	A8K0267-21	Copper	0.718	0.00200	1.3	ppm
190-CH1892-N/A-003-A	Room 121	11/7/2018	11/12/2018	A8K0267-21	Lead	2.71	0.200	15	ppb
190-CH1892-N/A-003-B	Room 121	11/7/2018	11/12/2018	A8K0267-22	Copper	0.186	0.00200	1.3	ppm
190-CH1892-N/A-003-B	Room 121	11/7/2018	11/12/2018	A8K0267-22	Lead	0.331	0.200	15	ppb
190-CH2007-N/A-003-A	Cafeteria Bubbler	11/7/2018	11/12/2018	A8K0267-35	Copper	0.0366	0.00200	1.3	ppm
190-CH2007-N/A-003-A	Cafeteria Bubbler	11/7/2018	11/12/2018	A8K0267-35	Lead	90.2	0.200	15	ppb
190-CH2007-N/A-003-B	Cafeteria Bubbler	11/7/2018	11/12/2018	A8K0267-36	Copper	0.00329	0.00200	1.3	ppm
190-CH2007-N/A-003-B	Cafeteria Bubbler	11/7/2018	11/12/2018	A8K0267-36	Lead	6.01	0.200	15	ppb
190-CH2008-N/A-003-A	Kitchen Food Prep Faucet	11/7/2018	11/12/2018	A8K0267-01	Copper	0.0409	0.00200	1.3	ppm
190-CH2008-N/A-003-A	Kitchen Food Prep Faucet	11/7/2018	11/12/2018	A8K0267-01	Lead	2.30	0.200	15	ppb
190-CH2008-N/A-003-B	Kitchen Food Prep Faucet	11/7/2018	11/12/2018	A8K0267-02	Copper	0.00288	0.00200	1.3	ppm
190-CH2008-N/A-003-B	Kitchen Food Prep Faucet	11/7/2018	11/12/2018	A8K0267-02	Lead	1.18	0.200	15	ppb
190-CH2010-N/A-003-A	Room 137	11/7/2018	11/12/2018	A8K0267-23	Copper	0.0299	0.00200	1.3	ppm
190-CH2010-N/A-003-A	Room 137	11/7/2018	11/12/2018	A8K0267-23	Lead	8.66	0.200	15	ppb
190-CH2010-N/A-003-B	Room 137	11/7/2018	11/12/2018	A8K0267-24	Copper	0.00466	0.00200	1.3	ppm
190-CH2010-N/A-003-B	Room 137	11/7/2018	11/12/2018	A8K0267-24	Lead	0.560	0.200	15	ppb

Analyzed by:
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

190-CH2012-N/A-003-A	Room 139	11/7/2018	11/12/2018	A8K0267-25	Copper	0.00554	0.00200	1.3	ppm
190-CH2012-N/A-003-A	Room 139	11/7/2018	11/12/2018	A8K0267-25	Lead	3.37	0.200	15	ppb
190-CH2012-N/A-003-B	Room 139	11/7/2018	11/12/2018	A8K0267-26	Copper	0.00343	0.00200	1.3	ppm
190-CH2012-N/A-003-B	Room 139	11/7/2018	11/12/2018	A8K0267-26	Lead	0.797	0.200	15	ppb
190-CH2013-A-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-29	Copper	0.154	0.00200	1.3	ppm
190-CH2013-A-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-29	Lead	31.5	0.200	15	ppb
190-CH2013-A-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-30	Copper	0.00795	0.00200	1.3	ppm
190-CH2013-A-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-30	Lead	0.837	0.200	15	ppb
190-CH2013-B-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-31	Copper	0.0306	0.00200	1.3	ppm
190-CH2013-B-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-31	Lead	2.17	0.200	15	ppb
190-CH2013-B-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-32	Copper	0.00774	0.00200	1.3	ppm
190-CH2013-B-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-32	Lead	0.563	0.200	15	ppb
190-CH2014-N/A-003-A	Room 45	11/7/2018	11/12/2018	A8K0267-27RE2	Copper	0.0214	0.00200	1.3	ppm
190-CH2014-N/A-003-A	Room 45	11/7/2018	11/12/2018	A8K0267-27RE2	Lead	1.41	0.200	15	ppb
190-CH2014-N/A-003-B	Room 45	11/7/2018	11/12/2018	A8K0267-28RE1	Copper	0.00427	0.00200	1.3	ppm
190-CH2014-N/A-003-B	Room 45	11/7/2018	11/12/2018	A8K0267-28RE1	Lead	0.593	0.200	15	ppb
190-CH2015-N/A-003-A	Room 106	11/7/2018	11/12/2018	A8K0267-03	Copper	0.0108	0.00200	1.3	ppm
190-CH2015-N/A-003-A	Room 106	11/7/2018	11/12/2018	A8K0267-03	Lead	2.95	0.200	15	ppb
190-CH2015-N/A-003-B	Room 106	11/7/2018	11/12/2018	A8K0267-04	Copper	0.00313	0.00200	1.3	ppm
190-CH2015-N/A-003-B	Room 106	11/7/2018	11/12/2018	A8K0267-04	Lead	2.10	0.200	15	ppb

Analyzed by:

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

190-CH2016-N/A-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-33	Copper	0.118	0.00200	1.3	ppm
190-CH2016-N/A-003-A	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-33	Lead	7.80	0.200	15	ppb
190-CH2016-N/A-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-34	Copper	0.00656	0.00200	1.3	ppm
190-CH2016-N/A-003-B	Hallway Bubbler	11/7/2018	11/12/2018	A8K0267-34	Lead	0.710	0.200	15	ppb
190-CH2017-N/A-003-A	Room 108	11/7/2018	11/12/2018	A8K0267-05	Copper	0.0594	0.00200	1.3	ppm
190-CH2017-N/A-003-A	Room 108	11/7/2018	11/12/2018	A8K0267-05	Lead	20.0	0.200	15	ppb
190-CH2017-N/A-003-B	Room 108	11/7/2018	11/12/2018	A8K0267-06RE1	Copper	0.0151	0.00200	1.3	ppm
190-CH2017-N/A-003-B	Room 108	11/7/2018	11/12/2018	A8K0267-06RE1	Lead	4.33	0.200	15	ppb
190-CH2018-N/A-003-A	Room 113	11/7/2018	11/12/2018	A8K0267-07RE1	Copper	0.00819	0.00200	1.3	ppm
190-CH2018-N/A-003-A	Room 113	11/7/2018	11/12/2018	A8K0267-07RE1	Lead	4.18	0.200	15	ppb
190-CH2018-N/A-003-B	Room 113	11/7/2018	11/12/2018	A8K0267-08	Copper	0.00314	0.00200	1.3	ppm
190-CH2018-N/A-003-B	Room 113	11/7/2018	11/12/2018	A8K0267-08	Lead	2.07	0.200	15	ppb
190-CH2019-N/A-003-A	Room 110	11/7/2018	11/12/2018	A8K0267-09	Copper	0.0141	0.00200	1.3	ppm
190-CH2019-N/A-003-A	Room 110	11/7/2018	11/12/2018	A8K0267-09	Lead	11.7	0.200	15	ppb
190-CH2019-N/A-003-B	Room 110	11/7/2018	11/12/2018	A8K0267-10	Copper	0.00388	0.00200	1.3	ppm
190-CH2019-N/A-003-B	Room 110	11/7/2018	11/12/2018	A8K0267-10	Lead	1.97	0.200	15	ppb
190-CH2020-N/A-003-A	Room 115	11/7/2018	11/12/2018	A8K0267-11	Copper	0.00685	0.00200	1.3	ppm
190-CH2020-N/A-003-A	Room 115	11/7/2018	11/12/2018	A8K0267-11	Lead	8.48	0.200	15	ppb
190-CH2020-N/A-003-B	Room 115	11/7/2018	11/12/2018	A8K0267-12	Copper	0.00255	0.00200	1.3	ppm
190-CH2020-N/A-003-B	Room 115	11/7/2018	11/12/2018	A8K0267-12	Lead	2.89	0.200	15	ppb

Analyzed by:

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

190-CH2021-N/A-003-A	Room 112	11/7/2018	11/12/2018	A8K0267-13	Copper	0.0149	0.00200	1.3	ppm
190-CH2021-N/A-003-A	Room 112	11/7/2018	11/12/2018	A8K0267-13	Lead	10.4	0.200	15	ppb
190-CH2021-N/A-003-B	Room 112	11/7/2018	11/12/2018	A8K0267-14	Copper	0.00316	0.00200	1.3	ppm
190-CH2021-N/A-003-B	Room 112	11/7/2018	11/12/2018	A8K0267-14	Lead	3.08	0.200	15	ppb
190-CH2022-N/A-003-A	Room 117	11/7/2018	11/12/2018	A8K0267-15	Copper	0.0117	0.00200	1.3	ppm
190-CH2022-N/A-003-A	Room 117	11/7/2018	11/12/2018	A8K0267-15	Lead	11.7	0.200	15	ppb
190-CH2022-N/A-003-B	Room 117	11/7/2018	11/12/2018	A8K0267-16RE1	Copper	0.00316	0.00200	1.3	ppm
190-CH2022-N/A-003-B	Room 117	11/7/2018	11/12/2018	A8K0267-16RE1	Lead	4.96	0.200	15	ppb
190-CH2023-N/A-003-A	Room 114	11/7/2018	11/12/2018	A8K0267-17	Copper	0.00718	0.00200	1.3	ppm
190-CH2023-N/A-003-A	Room 114	11/7/2018	11/12/2018	A8K0267-17	Lead	5.76	0.200	15	ppb
190-CH2023-N/A-003-B	Room 114	11/7/2018	11/12/2018	A8K0267-18	Copper	0.00268	0.00200	1.3	ppm
190-CH2023-N/A-003-B	Room 114	11/7/2018	11/12/2018	A8K0267-18	Lead	4.80	0.200	15	ppb
190-CH2024-N/A-003-A	Room 116	11/7/2018	11/12/2018	A8K0267-19	Copper	0.276	0.00200	1.3	ppm
190-CH2024-N/A-003-A	Room 116	11/7/2018	11/12/2018	A8K0267-19	Lead	7.59	0.200	15	ppb
190-CH2024-N/A-003-B	Room 116	11/7/2018	11/12/2018	A8K0267-20	Copper	0.351	0.00200	1.3	ppm
190-CH2024-N/A-003-B	Room 116	11/7/2018	11/12/2018	A8K0267-20	Lead	0.887	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental