

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Stephenson Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
190-CH2013-A-003-A	Hallway (33)	4/9/2019	4/22/2019	A9D0544-01	Lead	2.38	0.20	15	ppb
190-CH2013-B-003-A	Hallway (33)	4/9/2019	4/22/2019	A9D0544-03	Lead	1.15	0.20	15	ppb