

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Sunnyside School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
191-3791-A-001A Across from Rm 105	08/14/18 7:09 AM	08/17/18 2:49 PM	18019167	Copper	0.4	1.3	ppm
191-3791-A-001A Across from Rm 105	08/14/18 7:09 AM	08/17/18 2:49 PM	18019167	Lead	< 1	15	ppb
191-3791-A-001B Across from Rm 105	08/14/18 7:09 AM	08/17/18 2:51 PM	18019157	Copper	0.5	1.3	ppm
191-3791-A-001B Across from Rm 105	08/14/18 7:09 AM	08/17/18 2:51 PM	18019157	Lead	< 1	15	ppb
191-3788-A-001A Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:52 PM	18019166	Copper	0.3	1.3	ppm
191-3788-A-001A Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:52 PM	18019166	Lead	1	15	ppb
191-3788-A-001B Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:54 PM	18019165	Copper	0.4	1.3	ppm
191-3788-A-001B Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:54 PM	18019165	Lead	< 1	15	ppb
191-3788-B-001A Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:56 PM	18019154	Copper	0.4	1.3	ppm
191-3788-B-001A Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:56 PM	18019154	Lead	< 1	15	ppb
191-3788-B-001B Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:58 PM	18019153	Copper	0.4	1.3	ppm
191-3788-B-001B Across from Rm 105	08/14/18 7:12 AM	08/17/18 2:58 PM	18019153	Lead	< 1	15	ppb
191-3785-A-001A Across from Rm 105	08/14/18 7:15 AM	08/17/18 3:00 PM	18019152	Copper	0.4	1.3	ppm
191-3785-A-001A Across from Rm 105	08/14/18 7:15 AM	08/17/18 3:00 PM	18019152	Lead	2	15	ppb
191-3785-A-001B Across from Rm 105	08/14/18 7:15 AM	08/17/18 3:01 PM	18019158	Copper	0.5	1.3	ppm
191-3785-A-001B Across from Rm 105	08/14/18 7:15 AM	08/17/18 3:01 PM	18019158	Lead	< 1	15	ppb
191-3826-A-001A Kitchen	08/14/18 7:27 AM	08/17/18 3:03 PM	18019151	Copper	0.2	1.3	ppm
191-3826-A-001A Kitchen	08/14/18 7:27 AM	08/17/18 3:03 PM	18019151	Lead	< 1	15	ppb
191-3826-A-001B Kitchen	08/14/18 7:27 AM	08/17/18 3:05 PM	18019156	Copper	0.4	1.3	ppm
191-3826-A-001B Kitchen	08/14/18 7:27 AM	08/17/18 3:05 PM	18019156	Lead	< 1	15	ppb
191-3826-B-001A Kitchen	08/14/18 7:27 AM	08/17/18 3:18 PM	18019168	Copper	0.3	1.3	ppm
191-3826-B-001A Kitchen	08/14/18 7:27 AM	08/17/18 3:18 PM	18019168	Lead	< 1	15	ppb
191-3826-B-001B Kitchen	08/14/18 7:27 AM	08/17/18 3:20 PM	18019155	Copper	0.3	1.3	ppm
191-3826-B-001B Kitchen	08/14/18 7:27 AM	08/17/18 3:20 PM	18019155	Lead	< 1	15	ppb
191-3792-A-001A Across from Rm 207	08/14/18 7:35 AM	08/17/18 3:21 PM	18019160	Copper	0.4	1.3	ppm
191-3792-A-001A Across from Rm 207	08/14/18 7:35 AM	08/17/18 3:21 PM	18019160	Lead	< 1	15	ppb
191-3792-A-001B Across from Rm 207	08/14/18 7:35 AM	08/17/18 3:23 PM	18019161	Copper	0.5	1.3	ppm
191-3792-A-001B Across from Rm 207	08/14/18 7:35 AM	08/17/18 3:23 PM	18019161	Lead	< 1	15	ppb
191-3789-A-001A Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:25 PM	18019159	Copper	0.4	1.3	ppm
191-3789-A-001A Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:25 PM	18019159	Lead	< 1	15	ppb
191-3789-A-001B Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:27 PM	18019164	Copper	0.4	1.3	ppm
191-3789-A-001B Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:27 PM	18019164	Lead	< 1	15	ppb
191-3789-B-001A Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:29 PM	18019163	Copper	0.4	1.3	ppm
191-3789-B-001A Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:29 PM	18019163	Lead	< 1	15	ppb
191-3789-B-001B Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:30 PM	18019162	Copper	0.4	1.3	ppm
191-3789-B-001B Across from Rm 207	08/14/18 7:40 AM	08/17/18 3:30 PM	18019162	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation