

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Sunnyside Environmental School - Test 3**

| Sample Identification # | Location       | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|----------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 191-CH3801-N/A-003-A    | Staff Room 116 | 3/20/2019           | 3/29/2019     | A9C0792-01 | Lead    | 1.75    | 0.20            | 15                | ppb   |