

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Terwilliger School (Sunstone Montessori) - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
366-CH2221-A-002-A	Hallway (1)	5/23/2019	6/5/2019	A9E0811-24	Lead	21.80	0.20	15	ppb
366-CH2221-B-002-A	Hallway (1)	5/23/2019	6/5/2019	A9E0811-25	Lead	5.35	0.20	15	ppb
366-CH2221-C-002-A	Hallway (1)	5/23/2019	6/5/2019	A9E0811-26	Lead	1.92	0.20	15	ppb
366-CH2221-D-002-A	Hallway (1)	5/23/2019	6/5/2019	A9E0811-27	Lead	1.4	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.