

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Harriet Tubman Middle School

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
199-2103-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-01	Copper	0.0546	0.00200	1.3	ppm
199-2103-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-01	Lead	45.5	0.200	15	ppb
199-2103-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-02	Copper	0.0112	0.00200	1.3	ppm
199-2103-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-02	Lead	2.96	0.200	15	ppb
199-2104-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-03	Copper	0.114	0.00200	1.3	ppm
199-2104-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-03	Lead	63.4	0.200	15	ppb
199-2104-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-04	Copper	0.0103	0.00200	1.3	ppm
199-2104-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-04	Lead	4.65	0.200	15	ppb
199-2105-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-05	Copper	0.0912	0.00200	1.3	ppm
199-2105-N/A-001-A	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-05	Lead	59.7	0.200	15	ppb
199-2105-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-06	Copper	0.0226	0.00200	1.3	ppm
199-2105-N/A-001-B	Sink (Food Prep) - Room 159D	8/14/2018	8/21/2018	A8H0390-06	Lead	13.1	0.200	15	ppb
199-2125-N/A-001-A	Bottle Filler - Near 106	8/14/2018	8/21/2018	A8H0390-07	Copper	0.222	0.00200	1.3	ppm
199-2125-N/A-001-A	Bottle Filler - Near 106	8/14/2018	8/21/2018	A8H0390-07	Lead	0.247	0.200	15	ppb
199-2125-N/A-001-B	Bottle Filler - Near 106	8/14/2018	8/21/2018	A8H0390-08	Copper	0.256	0.00200	1.3	ppm
199-2125-N/A-001-B	Bottle Filler - Near 106	8/14/2018	8/21/2018	A8H0390-08	Lead	ND	0.200	15	ppb
199-2106-N/A-001-A	Gym	8/14/2018	8/23/2018	A8H0390-09RE1	Copper	0.0533	0.00200	1.3	ppm
199-2106-N/A-001-A	Gym	8/14/2018	8/22/2018	A8H0390-09	Lead	1.84	0.200	15	ppb
199-2106-N/A-001-B	Gym	8/14/2018	8/25/2018	A8H0390-10RE3	Copper	4.12	0.100	1.3	ppm
199-2106-N/A-001-B	Gym	8/14/2018	8/22/2018	A8H0390-10	Lead	42.1	0.200	15	ppb
199-2112-A-001-A	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-11	Copper	0.321	0.00200	1.3	ppm
199-2112-A-001-A	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-11	Lead	3.79	0.200	15	ppb
199-2112-A-001-B	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-12	Copper	0.569	0.00200	1.3	ppm

199-2112-A-001-B	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-12	Lead	3.95	0.200	15	ppb
199-2112-B-001-A	Food Prep Sprayer - Kitchen	8/14/2018	8/21/2018	A8H0390-13	Copper	0.319	0.00200	1.3	ppm
199-2112-B-001-A	Food Prep Sprayer - Kitchen	8/14/2018	8/21/2018	A8H0390-13	Lead	2.45	0.200	15	ppb
199-2112-B-001-B	Food Prep Sprayer - Kitchen	8/14/2018	8/21/2018	A8H0390-14	Copper	0.550	0.00200	1.3	ppm
199-2112-B-001-B	Food Prep Sprayer - Kitchen	8/14/2018	8/21/2018	A8H0390-14	Lead	3.94	0.200	15	ppb
199-2113-N/A-001-A	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-15	Copper	0.322	0.00200	1.3	ppm
199-2113-N/A-001-A	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-15	Lead	2.35	0.200	15	ppb
199-2113-N/A-001-B	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-16	Copper	0.521	0.00200	1.3	ppm
199-2113-N/A-001-B	Food Prep Faucet - Kitchen	8/14/2018	8/21/2018	A8H0390-16	Lead	3.70	0.200	15	ppb
199-2116-N/A-001-A	Bubbler - Cafeteria South Wall	8/14/2018	8/23/2018	A8H0390-17RE1	Copper	1.17	0.0100	1.3	ppm
199-2116-N/A-001-A	Bubbler - Cafeteria South Wall	8/14/2018	8/21/2018	A8H0390-17	Lead	1.78	0.200	15	ppb
199-2116-N/A-001-B	Bubbler - Cafeteria South Wall	8/14/2018	8/21/2018	A8H0390-18	Copper	0.904	0.00200	1.3	ppm
199-2116-N/A-001-B	Bubbler - Cafeteria South Wall	8/14/2018	8/21/2018	A8H0390-18	Lead	0.653	0.200	15	ppb
199-2103(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-19	Copper	0.444	0.00200	1.3	ppm
199-2103(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-19	Lead	7.60	0.200	15	ppb
199-2103(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-20	Copper	0.606	0.00200	1.3	ppm
199-2103(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-20	Lead	0.920	0.200	15	ppb
199-2104(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-21	Copper	0.617	0.00200	1.3	ppm
199-2104(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-21	Lead	214	0.200	15	ppb
199-2104(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/23/2018	A8H0390-22RE1	Copper	1.11	0.0100	1.3	ppm
199-2104(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-22	Lead	32.4	0.200	15	ppb
199-2105(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-23	Copper	0.440	0.00200	1.3	ppm
199-2105(132)-N/A-001-A	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-23	Lead	205	0.200	15	ppb
199-2105(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/23/2018	A8H0390-24RE1	Copper	1.19	0.0100	1.3	ppm
199-2105(132)-N/A-001-B	Sink (Food Prep) - Staff 132	8/14/2018	8/21/2018	A8H0390-24	Lead	26.4	0.200	15	ppb
199-2103(132A)-N/A-001-A	Sink (Food Prep) - Laundry 132A	8/14/2018	8/21/2018	A8H0390-25	Copper	0.568	0.00200	1.3	ppm
199-2103(132A)-N/A-001-A	Sink (Food Prep) - Laundry 132A	8/14/2018	8/21/2018	A8H0390-25	Lead	37.7	0.200	15	ppb
199-2103(132A)-N/A-001-B	Sink (Food Prep) - Laundry 132A	8/14/2018	8/21/2018	A8H0390-26	Copper	0.519	0.00200	1.3	ppm

199-2103(132A)-N/A-001-B	Sink (Food Prep) - Laundry 132A	8/14/2018	8/21/2018	A8H0390-26	Lead	5.60	0.200	15	ppb
199-2110-N/A-001-A	Bubbler - Room 131 (Stage)	8/14/2018	8/23/2018	A8H0390-27RE1	Copper	1.06	0.0100	1.3	ppm
199-2110-N/A-001-A	Bubbler - Room 131 (Stage)	8/14/2018	8/21/2018	A8H0390-27	Lead	16.5	0.200	15	ppb
199-2110-N/A-001-B	Bubbler - Room 131 (Stage)	8/14/2018	8/23/2018	A8H0390-28RE1	Copper	1.36	0.0100	1.3	ppm
199-2110-N/A-001-B	Bubbler - Room 131 (Stage)	8/14/2018	8/21/2018	A8H0390-28	Lead	4.19	0.200	15	ppb
199-2109-N/A-001-A	Sink Bubbler - Classroom 146	8/14/2018	8/23/2018	A8H0390-29RE1	Copper	1.32	0.0100	1.3	ppm
199-2109-N/A-001-A	Sink Bubbler - Classroom 146	8/14/2018	8/21/2018	A8H0390-29	Lead	15.4	0.200	15	ppb
199-2109-N/A-001-B	Sink Bubbler - Classroom 146	8/14/2018	8/23/2018	A8H0390-30RE1	Copper	1.76	0.0200	1.3	ppm
199-2109-N/A-001-B	Sink Bubbler - Classroom 146	8/14/2018	8/21/2018	A8H0390-30	Lead	3.70	0.200	15	ppb
199-2107-N/A-001-A	Left Bubbler - Near 154	8/14/2018	8/21/2018	A8H0390-31	Copper	0.673	0.00200	1.3	ppm
199-2107-N/A-001-A	Left Bubbler - Near 154	8/14/2018	8/23/2018	A8H0390-31RE1	Lead	2.25	0.200	15	ppb
199-2107-N/A-001-B	Left Bubbler - Near 154	8/14/2018	8/21/2018	A8H0390-32	Copper	0.489	0.00200	1.3	ppm
199-2107-N/A-001-B	Left Bubbler - Near 154	8/14/2018	8/23/2018	A8H0390-32RE1	Lead	0.412	0.200	15	ppb
199-2108-N/A-001-A	Right Bubbler - Near 154	8/14/2018	8/21/2018	A8H0390-33	Copper	0.369	0.00200	1.3	ppm
199-2108-N/A-001-A	Right Bubbler - Near 154	8/14/2018	8/23/2018	A8H0390-33RE1	Lead	1.37	0.200	15	ppb
199-2108-N/A-001-B	Right Bubbler - Near 154	8/14/2018	8/21/2018	A8H0390-34	Copper	0.322	0.00200	1.3	ppm
199-2108-N/A-001-B	Right Bubbler - Near 154	8/14/2018	8/23/2018	A8H0390-34RE1	Lead	0.365	0.200	15	ppb
199-2145-N/A-001-A	Drinking Fountain (Stainless) - Near 225	8/14/2018	8/21/2018	A8H0390-35	Copper	0.561	0.00200	1.3	ppm
199-2145-N/A-001-A	Drinking Fountain (Stainless) - Near 225	8/14/2018	8/23/2018	A8H0390-35RE1	Lead	2.07	0.200	15	ppb
199-2145-N/A-001-B	Drinking Fountain (Stainless) - Near 225	8/14/2018	8/21/2018	A8H0390-36	Copper	0.575	0.00200	1.3	ppm
199-2145-N/A-001-B	Drinking Fountain (Stainless) - Near 225	8/14/2018	8/23/2018	A8H0390-36RE1	Lead	1.30	0.200	15	ppb
199-2137-N/A-001-A	Bubbler - Near 215	8/14/2018	8/23/2018	A8H0390-37RE1	Copper	1.27	0.0200	1.3	ppm
199-2137-N/A-001-A	Bubbler - Near 215	8/14/2018	8/23/2018	A8H0390-37RE2	Lead	4.02	0.200	15	ppb
199-2137-N/A-001-B	Bubbler - Near 215	8/14/2018	8/23/2018	A8H0390-38RE1	Copper	1.06	0.0200	1.3	ppm
199-2137-N/A-001-B	Bubbler - Near 215	8/14/2018	8/23/2018	A8H0390-38RE2	Lead	1.24	0.200	15	ppb
199-2138-N/A-001-A	Sink Bubbler - Classroom 222	8/14/2018	8/21/2018	A8H0390-39	Copper	0.499	0.00200	1.3	ppm
199-2138-N/A-001-A	Sink Bubbler - Classroom 222	8/14/2018	8/23/2018	A8H0390-39RE1	Lead	4.27	0.200	15	ppb
199-2138-N/A-001-B	Sink Bubbler - Classroom 222	8/14/2018	8/21/2018	A8H0390-40	Copper	0.781	0.00200	1.3	ppm

199-2138-N/A-001-B	Sink Bubbler - Classroom 222	8/14/2018	8/23/2018	A8H0390-40RE1	Lead	4.99	0.200	15	ppb
199-2136-N/A-001-A	Sink Bubbler - Classroom 211	8/14/2018	8/21/2018	A8H0390-41	Copper	0.00780	0.00200	1.3	ppm
199-2136-N/A-001-A	Sink Bubbler - Classroom 211	8/14/2018	8/23/2018	A8H0390-41RE1	Lead	0.907	0.200	15	ppb
199-2136-N/A-001-B	Sink Bubbler - Classroom 211	8/14/2018	8/21/2018	A8H0390-42	Copper	0.00313	0.00200	1.3	ppm
199-2136-N/A-001-B	Sink Bubbler - Classroom 211	8/14/2018	8/23/2018	A8H0390-42RE1	Lead	0.387	0.200	15	ppb
199-2135-N/A-001-A	Sink - Classroom 209	8/14/2018	8/23/2018	A8H0390-43RE1	Copper	0.0785	0.00200	1.3	ppm
199-2135-N/A-001-A	Sink - Classroom 209	8/14/2018	8/23/2018	A8H0390-43RE1	Lead	6.06	0.200	15	ppb
199-2135-N/A-001-B	Sink - Classroom 209	8/14/2018	8/23/2018	A8H0390-44RE1	Copper	0.0527	0.00200	1.3	ppm
199-2135-N/A-001-B	Sink - Classroom 209	8/14/2018	8/23/2018	A8H0390-44RE1	Lead	1.97	0.200	15	ppb
199-2128-N/A-001-A	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-45RE1	Copper	0.0354	0.00200	1.3	ppm
199-2128-N/A-001-A	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-45RE1	Lead	12.2	0.200	15	ppb
199-2128-N/A-001-B	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-46RE1	Copper	0.263	0.00200	1.3	ppm
199-2128-N/A-001-B	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-46RE1	Lead	8.28	0.200	15	ppb
199-2127-N/A-001-A	Sink - Classroom 203	8/14/2018	8/23/2018	A8H0390-47RE1	Copper	0.0417	0.00200	1.3	ppm
199-2127-N/A-001-A	Sink - Classroom 203	8/14/2018	8/23/2018	A8H0390-47RE1	Lead	7.91	0.200	15	ppb
199-2127-N/A-001-B	Sink - Classroom 203	8/14/2018	8/23/2018	A8H0390-48RE1	Copper	0.0266	0.00200	1.3	ppm
199-2127-N/A-001-B	Sink - Classroom 203	8/14/2018	8/23/2018	A8H0390-48RE1	Lead	7.15	0.200	15	ppb
199-2131-N/A-001-A	Sink - Classroom 205	8/14/2018	8/23/2018	A8H0390-49RE1	Copper	0.0488	0.00200	1.3	ppm
199-2131-N/A-001-A	Sink - Classroom 205	8/14/2018	8/23/2018	A8H0390-49RE1	Lead	3.70	0.200	15	ppb
199-2131-N/A-001-B	Sink - Classroom 205	8/14/2018	8/23/2018	A8H0390-50RE1	Copper	0.0227	0.00200	1.3	ppm
199-2131-N/A-001-B	Sink - Classroom 205	8/14/2018	8/23/2018	A8H0390-50RE1	Lead	0.819	0.200	15	ppb
199-2132-N/A-001-A	Sink - Classroom 207	8/14/2018	8/23/2018	A8H0390-51RE1	Copper	0.0438	0.00200	1.3	ppm
199-2132-N/A-001-A	Sink - Classroom 207	8/14/2018	8/23/2018	A8H0390-51RE1	Lead	4.23	0.200	15	ppb
199-2132-N/A-001-B	Sink - Classroom 207	8/14/2018	8/23/2018	A8H0390-52RE1	Copper	0.0134	0.00200	1.3	ppm
199-2132-N/A-001-B	Sink - Classroom 207	8/14/2018	8/23/2018	A8H0390-52RE1	Lead	1.43	0.200	15	ppb
199-2147-N/A-001-A	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-53RE1	Copper	0.305	0.00200	1.3	ppm
199-2147-N/A-001-A	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-53RE1	Lead	32.8	0.200	15	ppb
199-2147-N/A-001-B	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-54RE1	Copper	0.517	0.00200	1.3	ppm

199-2147-N/A-001-B	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-54RE1	Lead	22.2	0.200	15	ppb
199-2146-N/A-001-A	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-55RE1	Copper	0.278	0.00200	1.3	ppm
199-2146-N/A-001-A	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-55RE1	Lead	10.9	0.200	15	ppb
199-2146-N/A-001-B	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-56RE1	Copper	0.447	0.00200	1.3	ppm
199-2146-N/A-001-B	Sink Bubbler - Staff 181	8/14/2018	8/23/2018	A8H0390-56RE1	Lead	10.5	0.200	15	ppb
199-2102-N/A-001-A	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-57RE1	Copper	0.0409	0.00200	1.3	ppm
199-2102-N/A-001-A	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-57RE1	Lead	13.1	0.200	15	ppb
199-2102-N/A-001-B	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-58RE1	Copper	0.0189	0.00200	1.3	ppm
199-2102-N/A-001-B	Bubbler - Hallway	8/14/2018	8/23/2018	A8H0390-58RE1	Lead	15.7	0.200	15	ppb
199-2122-N/A-001-A	Sink Bubbler - Classroom 113	8/14/2018	8/23/2018	A8H0390-59RE1	Copper	0.0780	0.00200	1.3	ppm
199-2122-N/A-001-A	Sink Bubbler - Classroom 113	8/14/2018	8/23/2018	A8H0390-59RE1	Lead	6.67	0.200	15	ppb
199-2122-N/A-001-B	Sink Bubbler - Classroom 113	8/14/2018	8/23/2018	A8H0390-60RE1	Copper	0.0248	0.00200	1.3	ppm
199-2122-N/A-001-B	Sink Bubbler - Classroom 113	8/14/2018	8/23/2018	A8H0390-60RE1	Lead	1.17	0.200	15	ppb
199-2121-N/A-001-A	Sink Bubbler - Classroom 115	8/14/2018	8/23/2018	A8H0390-61RE1	Copper	0.109	0.00200	1.3	ppm
199-2121-N/A-001-A	Sink Bubbler - Classroom 115	8/14/2018	8/23/2018	A8H0390-61RE1	Lead	2.57	0.200	15	ppb
199-2121-N/A-001-B	Sink Bubbler - Classroom 115	8/14/2018	8/23/2018	A8H0390-62RE1	Copper	0.0516	0.00200	1.3	ppm
199-2121-N/A-001-B	Sink Bubbler - Classroom 115	8/14/2018	8/23/2018	A8H0390-62RE1	Lead	1.15	0.200	15	ppb
199-2124-N/A-001-A	Sink Bubbler - Classroom 118	8/14/2018	8/28/2018	A8H0390-63RE2	Copper	0.0953	0.00200	1.3	ppm
199-2124-N/A-001-A	Sink Bubbler - Classroom 118	8/14/2018	8/28/2018	A8H0390-63RE2	Lead	31.6	0.200	15	ppb
199-2124-N/A-001-B	Sink Bubbler - Classroom 118	8/14/2018	8/28/2018	A8H0390-64RE2	Copper	0.0286	0.00200	1.3	ppm
199-2124-N/A-001-B	Sink Bubbler - Classroom 118	8/14/2018	8/28/2018	A8H0390-64RE2	Lead	8.48	0.200	15	ppb
199-2123-N/A-001-A	Sink Bubbler - Classroom 120	8/14/2018	8/28/2018	A8H0390-65RE2	Copper	0.0746	0.00200	1.3	ppm
199-2123-N/A-001-A	Sink Bubbler - Classroom 120	8/14/2018	8/28/2018	A8H0390-65RE2	Lead	9.65	0.200	15	ppb
199-2123-N/A-001-B	Sink Bubbler - Classroom 120	8/14/2018	8/28/2018	A8H0390-66RE2	Copper	0.0224	0.00200	1.3	ppm
199-2123-N/A-001-B	Sink Bubbler - Classroom 120	8/14/2018	8/28/2018	A8H0390-66RE2	Lead	3.23	0.200	15	ppb
199-2118-N/A-001-A	Sink Bubbler - Classroom 117	8/14/2018	8/28/2018	A8H0390-67RE2	Copper	0.0849	0.00200	1.3	ppm
199-2118-N/A-001-A	Sink Bubbler - Classroom 117	8/14/2018	8/28/2018	A8H0390-67RE2	Lead	4.87	0.200	15	ppb
199-2118-N/A-001-B	Sink Bubbler - Classroom 117	8/14/2018	8/28/2018	A8H0390-68RE2	Copper	0.0546	0.00200	1.3	ppm

199-2118-N/A-001-B	Sink Bubbler - Classroom 117	8/14/2018	8/28/2018	A8H0390-68RE2	Lead	3.50	0.200	15	ppb
199-2117-N/A-001-A	Sink Bubbler - Classroom 119	8/14/2018	8/28/2018	A8H0390-69RE2	Copper	0.114	0.00200	1.3	ppm
199-2117-N/A-001-A	Sink Bubbler - Classroom 119	8/14/2018	8/28/2018	A8H0390-69RE2	Lead	3.85	0.200	15	ppb
199-2117-N/A-001-B	Sink Bubbler - Classroom 119	8/14/2018	8/28/2018	A8H0390-70RE2	Copper	0.110	0.00200	1.3	ppm
199-2117-N/A-001-B	Sink Bubbler - Classroom 119	8/14/2018	8/28/2018	A8H0390-70RE2	Lead	1.20	0.200	15	ppb
199-2119-N/A-001-A	Sink Bubbler - Classroom 124	8/14/2018	8/28/2018	A8H0390-71RE2	Copper	0.0214	0.00200	1.3	ppm
199-2119-N/A-001-A	Sink Bubbler - Classroom 124	8/14/2018	8/28/2018	A8H0390-71RE2	Lead	10.4	0.200	15	ppb
199-2119-N/A-001-B	Sink Bubbler - Classroom 124	8/14/2018	8/28/2018	A8H0390-72RE2	Copper	0.0718	0.00200	1.3	ppm
199-2119-N/A-001-B	Sink Bubbler - Classroom 124	8/14/2018	8/28/2018	A8H0390-72RE2	Lead	19.6	0.200	15	ppb
199-2120-N/A-001-A	Sink Bubbler - Classroom 122	8/14/2018	8/28/2018	A8H0390-73RE2	Copper	0.150	0.00200	1.3	ppm
199-2120-N/A-001-A	Sink Bubbler - Classroom 122	8/14/2018	8/28/2018	A8H0390-73RE2	Lead	4.50	0.200	15	ppb
199-2120-N/A-001-B	Sink Bubbler - Classroom 122	8/14/2018	8/28/2018	A8H0390-74RE2	Copper	0.0886	0.00200	1.3	ppm
199-2120-N/A-001-B	Sink Bubbler - Classroom 122	8/14/2018	8/28/2018	A8H0390-74RE2	Lead	4.92	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.