Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Harriet Tubman Middle School - Test 2

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
199-CH2106-N/A-002-A	Gym	4/12/2019	4/22/2019	A9D0548-01	Lead	8.68	0.20	15	ppb
199-CH2115-N/A-002-A	Classroom 132	4/12/2019	4/24/2019	A9D0548-02	Lead	25.80	0.20	15	ppb
199-CH2126-N/A-002-A	Classroom 201	4/12/2019	4/24/2019	A9D0548-03	Lead	2.71	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek