

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Vernon Elementary**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
284-CH1686-N/A-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-01RE1	Copper	0.916	0.01	1.3	ppm
284-CH1686-N/A-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-01	Lead	0.682	0.2	15	ppb
284-CH1686-N/A-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-02RE1	Copper	1.12	0.01	1.3	ppm
284-CH1686-N/A-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-02	Lead	ND	0.2	15	ppb
284-CH1697-N/A-001-A	Gym Bubbler	5/16/2018	5/22/2018	A8E0501-03RE1	Copper	0.762	0.01	1.3	ppm
284-CH1697-N/A-001-A	Gym Bubbler	5/16/2018	5/22/2018	A8E0501-03	Lead	0.674	0.2	15	ppb
284-CH1697-N/A-001-B	Gym Bubbler	5/16/2018	5/22/2018	A8E0501-04RE1	Copper	0.768	0.01	1.3	ppm
284-CH1697-N/A-001-B	Gym Bubbler	5/16/2018	5/22/2018	A8E0501-04	Lead	ND	0.2	15	ppb
284-CH1759-A-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-05	Copper	0.437	0.001	1.3	ppm
284-CH1759-A-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-05	Lead	0.571	0.2	15	ppb
284-CH1759-A-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-06RE1	Copper	0.745	0.01	1.3	ppm
284-CH1759-A-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-06	Lead	ND	0.2	15	ppb
284-CH1759-B-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-07RE1	Copper	0.654	0.01	1.3	ppm
284-CH1759-B-001-A	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-07RE1	Lead	0.361	0.2	15	ppb
284-CH1759-B-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-08	Copper	0.362	0.001	1.3	ppm
284-CH1759-B-001-B	Hall Bubbler	5/16/2018	5/22/2018	A8E0501-08	Lead	ND	0.2	15	ppb
284-CH1769-N/A-001-A	Cafeteria Bubbler	5/16/2018	5/22/2018	A8E0501-09	Copper	0.201	0.001	1.3	ppm

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

284-CH1769-N/A-001-A	Cafeteria Bubbler	5/16/2018	5/22/2018	A8E0501-09	Lead	0.3	0.2	15	ppb
284-CH1769-N/A-001-B	Cafeteria Bubbler	5/16/2018	5/22/2018	A8E0501-10	Copper	0.0727	0.001	1.3	ppm
284-CH1769-N/A-001-B	Cafeteria Bubbler	5/16/2018	5/22/2018	A8E0501-10	Lead	ND	0.2	15	ppb