

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Vernon K-8 School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
284-CH1694-N/A-003-A	Classroom 103	4/10/2019	4/24/2019	A9D0547-01	Lead	2.48	0.20	15	ppb
284-P5-302-N/A-003-A	Classroom P5/302	4/10/2019	4/24/2019	A9D0547-03	Lead	1.76	0.20	15	ppb
284-P4-301-N/A-003-A	Classroom P4/301	4/10/2019	4/24/2019	A9D0547-05	Lead	1.13	0.20	15	ppb
284-CH1757-N/A-003-A	Classroom 117	4/10/2019	4/24/2019	A9D0547-07	Lead	1.33	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb