

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Vestal Elementary

Sample Identification #		Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
286-5446-A-001-A		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-01	Copper	0.0198	0.00200	1.3	ppm
286-5446-A-001-A		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-01	Lead	2.36	0.200	15	ppb
286-5446-A-001-B		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-02	Copper	0.00353	0.00200	1.3	ppm
286-5446-A-001-B		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-02	Lead	0.481	0.200	15	ppb
286-5446-B-001-A		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-03	Copper	0.0216	0.00200	1.3	ppm
286-5446-B-001-A		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-03	Lead	1.61	0.200	15	ppb
286-5446-B-001-B		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-04	Copper	0.00296	0.00200	1.3	ppm
286-5446-B-001-B		Bubbler - Across from 102	7/31/2018	8/2/2018	A8G0811-04	Lead	0.412	0.200	15	ppb
286-5434-N/A-001-A		Bubbler - Next to Gym	7/31/2018	8/3/2018	A8G0811-05	Copper	0.100	0.00200	1.3	ppm
286-5434-N/A-001-A		Bubbler - Next to Gym	7/31/2018	8/3/2018	A8G0811-05	Lead	5.59	0.200	15	ppb
286-5434-N/A-001-B		Bubbler - Next to Gym	7/31/2018	8/2/2018	A8G0811-06	Copper	0.00596	0.00200	1.3	ppm
286-5434-N/A-001-B		Bubbler - Next to Gym	7/31/2018	8/2/2018	A8G0811-06	Lead	0.860	0.200	15	ppb
286-5437-N/A-001-A		Drinking Fountain (Stainless) - Near Gym, base of Stairs	7/31/2018	8/3/2018	A8G0811-07	Copper	0.00810	0.00200	1.3	ppm
286-5437-N/A-001-A		Drinking Fountain (Stainless) - Near Gym, base of Stairs	7/31/2018	8/3/2018	A8G0811-07	Lead	1.63	0.200	15	ppb
286-5437-N/A-001-B		Drinking Fountain (Stainless) - Near Gym, base of Stairs	7/31/2018	8/2/2018	A8G0811-08	Copper	0.00319	0.00200	1.3	ppm
286-5437-N/A-001-B		Drinking Fountain (Stainless) - Near Gym, base of Stairs	7/31/2018	8/2/2018	A8G0811-08	Lead	0.385	0.200	15	ppb
286-5451-A-001-A		Food Prep Sprayer - Kitchen	7/31/2018	8/2/2018	A8G0811-09	Copper	0.0514	0.00200	1.3	ppm
286-5451-A-001-A		Food Prep Sprayer - Kitchen	7/31/2018	8/2/2018	A8G0811-09	Lead	5.31	0.200	15	ppb
286-5451-A-001-B		Food Prep Sprayer - Kitchen	7/31/2018	8/3/2018	A8G0811-10	Copper	0.0705	0.00200	1.3	ppm
286-5451-A-001-B		Food Prep Sprayer - Kitchen	7/31/2018	8/3/2018	A8G0811-10	Lead	6.22	0.200	15	ppb
286-5451-B-001-A		Food Prep Faucet - Kitchen	7/31/2018	8/3/2018	A8G0811-11	Copper	0.129	0.00200	1.3	ppm
286-5451-B-001-A		Food Prep Faucet - Kitchen	7/31/2018	8/3/2018	A8G0811-11	Lead	2.69	0.200	15	ppb
286-5451-B-001-B		Food Prep Faucet - Kitchen	7/31/2018	8/3/2018	A8G0811-12	Copper	0.0827	0.00200	1.3	ppm

286-5451-B-001-B	Food Prep Faucet - Kitchen	7/31/2018	8/3/2018	A8G0811-12	Lead	7.35	0.200	15	ppb
286-5436-A-001-A	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-13	Copper	0.0351	0.00200	1.3	ppm
286-5436-A-001-A	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-13	Lead	11.0	0.200	15	ppb
286-5436-A-001-B	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-14	Copper	0.00368	0.00200	1.3	ppm
286-5436-A-001-B	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-14	Lead	1.19	0.200	15	ppb
286-5436-B-001-A	Bubbler - Across from 110	7/31/2018	8/3/2018	A8G0811-15	Copper	0.0228	0.00200	1.3	ppm
286-5436-B-001-A	Bubbler - Across from 110	7/31/2018	8/3/2018	A8G0811-15	Lead	8.95	0.200	15	ppb
286-5436-B-001-B	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-16	Copper	0.00373	0.00200	1.3	ppm
286-5436-B-001-B	Bubbler - Across from 110	7/31/2018	8/2/2018	A8G0811-16	Lead	1.26	0.200	15	ppb
286-5455-A-001-A	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-17	Copper	0.0229	0.00200	1.3	ppm
286-5455-A-001-A	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-17	Lead	8.22	0.200	15	ppb
286-5455-A-001-B	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-18	Copper	0.00663	0.00200	1.3	ppm
286-5455-A-001-B	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-18	Lead	2.70	0.200	15	ppb
286-5455-B-001-A	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-19	Copper	0.0432	0.00200	1.3	ppm
286-5455-B-001-A	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-19	Lead	6.89	0.200	15	ppb
286-5455-B-001-B	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-20	Copper	0.00693	0.00200	1.3	ppm
286-5455-B-001-B	Bubbler - Across from 213	7/31/2018	8/2/2018	A8G0811-20	Lead	2.57	0.200	15	ppb
286-5489-A-001-A	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-21	Copper	0.0230	0.00200	1.3	ppm
286-5489-A-001-A	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-21	Lead	7.50	0.200	15	ppb
286-5489-A-001-B	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-22	Copper	0.00484	0.00200	1.3	ppm
286-5489-A-001-B	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-22	Lead	2.08	0.200	15	ppb
286-5489-B-001-A	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-23	Copper	0.0194	0.00200	1.3	ppm
286-5489-B-001-A	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-23	Lead	7.40	0.200	15	ppb
286-5489-B-001-B	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-24	Copper	0.00268	0.00200	1.3	ppm
286-5489-B-001-B	Bubbler - Left of 209	7/31/2018	8/2/2018	A8G0811-24	Lead	2.18	0.200	15	ppb
286-5492-A-001-A	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-25	Copper	0.0289	0.00200	1.3	ppm
286-5492-A-001-A	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-25	Lead	3.08	0.200	15	ppb
286-5492-A-001-B	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-26	Copper	0.00344	0.00200	1.3	ppm

286-5492-A-001-B	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-26	Lead	2.52	0.200	15	ppb
286-5492-B-001-A	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-27	Copper	0.0226	0.00200	1.3	ppm
286-5492-B-001-A	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-27	Lead	2.65	0.200	15	ppb
286-5492-B-001-B	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-28	Copper	0.00296	0.00200	1.3	ppm
286-5492-B-001-B	Bubbler - Across from 208	7/31/2018	8/2/2018	A8G0811-28	Lead	2.51	0.200	15	ppb
286-5495-A-001-A	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-29	Copper	0.0161	0.00200	1.3	ppm
286-5495-A-001-A	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-29	Lead	1.86	0.200	15	ppb
286-5495-A-001-B	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-30	Copper	0.00361	0.00200	1.3	ppm
286-5495-A-001-B	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-30	Lead	0.639	0.200	15	ppb
286-5495-B-001-A	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-31	Copper	0.0259	0.00200	1.3	ppm
286-5495-B-001-A	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-31	Lead	2.56	0.200	15	ppb
286-5495-B-001-B	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-32	Copper	0.00310	0.00200	1.3	ppm
286-5495-B-001-B	Bubbler - Across/Outside 202	7/31/2018	8/2/2018	A8G0811-32	Lead	0.629	0.200	15	ppb