

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
West Sylvan Middle School

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
196-2092-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 164	8/8/2018	8/17/2018	A8H0206-01	Lead	13.4	0.200	15	ppb
196-2092-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 164	8/8/2018	8/21/2018	A8H0206-01RE1	Copper	0.0613	0.00200	1.3	ppm
196-2092-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 164	8/8/2018	8/17/2018	A8H0206-02	Lead	6.91	0.200	15	ppm
196-2092-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 164	8/8/2018	8/21/2018	A8H0206-02RE1	Copper	0.0469	0.00200	1.3	ppb
196-2101-N/A-001-A	Sink (Food Prep) - Office 101	8/8/2018	8/17/2018	A8H0206-03	Lead	3.86	0.200	15	ppm
196-2101-N/A-001-A	Sink (Food Prep) - Office 101	8/8/2018	8/21/2018	A8H0206-03RE1	Copper	0.0404	0.00200	1.3	ppb
196-2101-N/A-001-B	Sink (Food Prep) - Office 101	8/8/2018	8/17/2018	A8H0206-04	Lead	0.784	0.200	15	ppm
196-2101-N/A-001-B	Sink (Food Prep) - Office 101	8/8/2018	8/21/2018	A8H0206-04RE1	Copper	0.00612	0.00200	1.3	ppb
196-2098-N/A-001-A	Drinking Fountain (Metal) - Hallway Near 108	8/8/2018	8/17/2018	A8H0206-05	Lead	1.18	0.200	15	ppm
196-2098-N/A-001-A	Drinking Fountain (Metal) - Hallway Near 108	8/8/2018	8/21/2018	A8H0206-05RE1	Copper	0.0203	0.00200	1.3	ppb
196-2098-N/A-001-B	Drinking Fountain (Metal) - Hallway Near 108	8/8/2018	8/17/2018	A8H0206-06	Lead	2.33	0.200	15	ppm
196-2098-N/A-001-B	Drinking Fountain (Metal) - Hallway Near 108	8/8/2018	8/21/2018	A8H0206-06RE1	Copper	0.0103	0.00200	1.3	ppb
196-2100-N/A-001-A	Sink (Food Prep) - Staff 119	8/8/2018	8/17/2018	A8H0206-07	Lead	20.0	0.200	15	ppm
196-2100-N/A-001-A	Sink (Food Prep) - Staff 119	8/8/2018	8/17/2018	A8H0206-07	Copper	0.177	0.00200	1.3	ppb
196-2100-N/A-001-B	Sink (Food Prep) - Staff 119	8/8/2018	8/17/2018	A8H0206-08	Lead	5.51	0.200	15	ppm
196-2100-N/A-001-B	Sink (Food Prep) - Staff 119	8/8/2018	8/17/2018	A8H0206-08	Copper	0.254	0.00200	1.3	ppb
196-2095-N/A-001-A	Sink (Food Prep) - Media/Library 137	8/8/2018	8/17/2018	A8H0206-09	Lead	49.0	0.200	15	ppm
196-2095-N/A-001-A	Sink (Food Prep) - Media/Library 137	8/8/2018	8/17/2018	A8H0206-09	Copper	0.499	0.00200	1.3	ppb
196-2095-N/A-001-B	Sink (Food Prep) - Media/Library 137	8/8/2018	8/17/2018	A8H0206-10	Lead	41.3	0.200	15	ppm
196-2095-N/A-001-B	Sink (Food Prep) - Media/Library 137	8/8/2018	8/17/2018	A8H0206-10	Copper	0.492	0.00200	1.3	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.