

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Whitman Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level*	Units
290-1256-A-001A Kitchen Sprayer	08/01/18 10:05 AM	08/06/18 12:05 PM	18017201	Copper	<0.1	1.3	ppm
290-1256-A-001A Kitchen Sprayer	08/01/18 10:05 AM	08/06/18 12:05 PM	18017201	Lead	2	15	ppb
290-1256-A-001B Kitchen Sprayer	08/01/18 10:05 AM	08/06/18 12:07 PM	18017191	Copper	<0.1	1.3	ppm
290-1256-A-001B Kitchen Sprayer	08/01/18 10:05 AM	08/06/18 12:07 PM	18017191	Lead	<1	15	ppb
290-1256-B-001A Kitchen Faucet	08/01/18 10:09 AM	08/06/18 12:09 PM	18017197	Copper	0.1	1.3	ppm
290-1256-B-001A Kitchen Faucet	08/01/18 10:09 AM	08/06/18 12:09 PM	18017197	Lead	2	15	ppb
290-1256-B-001B Kitchen Faucet	08/01/18 10:09 AM	08/06/18 12:10 PM	18017198	Copper	<0.1	1.3	ppm
290-1256-B-001B Kitchen Faucet	08/01/18 10:09 AM	08/06/18 12:10 PM	18017198	Lead	2	15	ppb
290-1258-A-001A Outside Gym	08/01/18 10:19 AM	08/06/18 12:12 PM	18017195	Copper	<0.1	1.3	ppm
290-1258-A-001A Outside Gym	08/01/18 10:19 AM	08/06/18 12:12 PM	18017195	Lead	13	15	ppb
290-1258-A-001B Outside Gym	08/01/18 10:19 AM	08/06/18 12:14 PM	18017204	Copper	<0.1	1.3	ppm
290-1258-A-001B Outside Gym	08/01/18 10:19 AM	08/06/18 12:14 PM	18017204	Lead	5	15	ppb
290-1250-A-001A Next to Custodian 1	08/01/18 10:26 AM	08/06/18 12:16 PM	18017200	Copper	<0.1	1.3	ppm
290-1250-A-001A Next to Custodian 1	08/01/18 10:26 AM	08/06/18 12:16 PM	18017200	Lead	9	15	ppb
290-1250-A-001B Next to Custodian 1	08/01/18 10:26 AM	08/06/18 12:18 PM	18017202	Copper	<0.1	1.3	ppm
290-1250-A-001B Next to Custodian 1	08/01/18 10:26 AM	08/06/18 12:18 PM	18017202	Lead	9	15	ppb
290-1226-A-001A Across from Rm 22	08/01/18 10:34 AM	08/06/18 12:19 PM	18017203	Copper	<0.1	1.3	ppm
290-1226-A-001A Across from Rm 22	08/01/18 10:34 AM	08/06/18 12:19 PM	18017203	Lead	7	15	ppb
290-1226-A-001B Across from Rm 22	08/01/18 10:34 AM	08/06/18 12:43 PM	18017194	Copper	<0.1	1.3	ppm
290-1226-A-001B Across from Rm 22	08/01/18 10:34 AM	08/06/18 12:43 PM	18017194	Lead	1	15	ppb
290-1242-A-001A Across from Rm 17	08/01/18 10:41 AM	08/06/18 12:45 PM	18017193	Copper	0.1	1.3	ppm
290-1242-A-001A Across from Rm 17	08/01/18 10:41 AM	08/06/18 12:45 PM	18017193	Lead	5	15	ppb
290-1242-A-001B Across from Rm 17	08/01/18 10:41 AM	08/06/18 12:47 PM	18017196	Copper	0.1	1.3	ppm
290-1242-A-001B Across from Rm 17	08/01/18 10:41 AM	08/06/18 12:47 PM	18017196	Lead	6	15	ppb
290-1236-A-001A Next to Custodian 4	08/01/18 10:49 AM	08/06/18 12:48 PM	18017199	Copper	0.1	1.3	ppm
290-1236-A-001A Next to Custodian 4	08/01/18 10:49 AM	08/06/18 12:48 PM	18017199	Lead	3	15	ppb
290-1236-A-001B Next to Custodian 4	08/01/18 10:49 AM	08/06/18 12:50 PM	18017192	Copper	0.1	1.3	ppm
290-1236-A-001B Next to Custodian 4	08/01/18 10:49 AM	08/06/18 12:50 PM	18017192	Lead	<1	15	ppb
290-1264-A-001A Across from Rm 6	08/01/18 10:59 AM	08/06/18 12:52 PM	18017206	Copper	<0.1	1.3	ppm
290-1264-A-001A Across from Rm 6	08/01/18 10:59 AM	08/06/18 12:52 PM	18017206	Lead	4	15	ppb
290-1264-A-001B Across from Rm 6	08/01/18 10:59 AM	08/06/18 1:01 PM	18017205	Copper	<0.1	1.3	ppm
290-1264-A-001B Across from Rm 6	08/01/18 10:59 AM	08/06/18 1:01 PM	18017205	Lead	3	15	ppb
290-1269-A-001A Across from Rm 9	08/01/18 11:05 AM	08/06/18 1:03 PM	18017188	Copper	<0.1	1.3	ppm
290-1269-A-001A Across from Rm 9	08/01/18 11:05 AM	08/06/18 1:03 PM	18017188	Lead	9	15	ppb
290-1269-A-001B Across from Rm 9	08/01/18 11:05 AM	08/06/18 1:05 PM	18017189	Copper	<0.1	1.3	ppm
290-1269-A-001B Across from Rm 9	08/01/18 11:05 AM	08/06/18 1:05 PM	18017189	Lead	2	15	ppb
290-1261-A-001A Gym	08/01/18 11:14 AM	08/06/18 1:06 PM	18017190	Copper	<0.1	1.3	ppm
290-1261-A-001A Gym	08/01/18 11:14 AM	08/06/18 1:06 PM	18017190	Lead	4	15	ppb
290-1261-A-001B Gym	08/01/18 11:14 AM	08/06/18 1:08 PM	18017185	Copper	<0.1	1.3	ppm
290-1261-A-001B Gym	08/01/18 11:14 AM	08/06/18 1:08 PM	18017185	Lead	2	15	ppb
290-1253-A-001A Cafeteria next to Rm 2	08/01/18 11:22 AM	08/06/18 1:10 PM	18017186	Copper	<0.1	1.3	ppm
290-1253-A-001A Cafeteria next to Rm 2	08/01/18 11:22 AM	08/06/18 1:10 PM	18017186	Lead	8	15	ppb
290-1253-A-001B Cafeteria next to Rm 2	08/01/18 11:22 AM	08/06/18 1:12 PM	18017187	Copper	<0.1	1.3	ppm
290-1253-A-001B Cafeteria next to Rm 2	08/01/18 11:22 AM	08/06/18 1:12 PM	18017187	Lead	7	15	ppb
290-1251-A-001A Cafeteria next to Hall Door 2	08/01/18 11:30 AM	08/06/18 1:14 PM	18017207	Copper	<0.1	1.3	ppm
290-1251-A-001A Cafeteria next to Hall Door 2	08/01/18 11:30 AM	08/06/18 1:14 PM	18017207	Lead	14	15	ppb
290-1251-A-001B Cafeteria next to Hall Door 2	08/01/18 11:30 AM	08/06/18 1:15 PM	18017208	Copper	<0.1	1.3	ppm
290-1251-A-001B Cafeteria next to Hall Door 2	08/01/18 11:30 AM	08/06/18 1:15 PM	18017208	Lead	7	15	ppb

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: TRC Environmental Corporation