

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Whitman

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
290-CH1225-N/A-002-A	Classroom 10	11/1/2018	11/5/2018	A8K0049-17	Copper	0.0835	0.00200	1.3	ppm
290-CH1225-N/A-002-A	Classroom 10	11/1/2018	11/5/2018	A8K0049-17	Lead	6.02	4.00	15	ppb
290-CH1225-N/A-002-B	Classroom 10	11/1/2018	11/5/2018	A8K0049-18	Copper	0.0691	0.00200	1.3	ppm
290-CH1225-N/A-002-B	Classroom 10	11/1/2018	11/5/2018	A8K0049-18RE1	Lead	2.19	0.200	15	ppb
290-CH1228-N/A-002-A	Classroom 14	11/1/2018	11/5/2018	A8K0049-11	Copper	0.0273	0.00200	1.3	ppm
290-CH1228-N/A-002-A	Classroom 14	11/1/2018	11/5/2018	A8K0049-11RE1	Lead	1.73	0.200	15	ppb
290-CH1228-N/A-002-B	Classroom 14	11/1/2018	11/5/2018	A8K0049-12	Copper	0.0203	0.00200	1.3	ppm
290-CH1228-N/A-002-B	Classroom 14	11/1/2018	11/5/2018	A8K0049-12RE1	Lead	1.22	0.200	15	ppb
290-CH1230-N/A-002-A	Classroom 15	11/1/2018	11/5/2018	A8K0049-09	Copper	0.474	0.00200	1.3	ppm
290-CH1230-N/A-002-A	Classroom 15	11/1/2018	11/5/2018	A8K0049-09	Lead	26.0	0.200	15	ppb
290-CH1230-N/A-002-B	Classroom 15	11/1/2018	11/5/2018	A8K0049-10	Copper	0.856	0.00200	1.3	ppm
290-CH1230-N/A-002-B	Classroom 15	11/1/2018	11/5/2018	A8K0049-10	Lead	25.5	0.200	15	ppb
290-CH1232-N/A-002-A	Classroom 18	11/1/2018	11/5/2018	A8K0049-05	Copper	0.0660	0.00200	1.3	ppm
290-CH1232-N/A-002-A	Classroom 18	11/1/2018	11/5/2018	A8K0049-05	Lead	2.46	0.200	15	ppb
290-CH1232-N/A-002-B	Classroom 18	11/1/2018	11/5/2018	A8K0049-06	Copper	0.0348	0.00200	1.3	ppm
290-CH1232-N/A-002-B	Classroom 18	11/1/2018	11/5/2018	A8K0049-06	Lead	1.40	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 1 of 4

290-CH1234-N/A-002-A	Classroom 21	11/1/2018	11/5/2018	A8K0049-03	Copper	0.0406	0.00200	1.3	ppm
290-CH1234-N/A-002-A	Classroom 21	11/1/2018	11/5/2018	A8K0049-03	Lead	2.50	0.200	15	ppb
290-CH1234-N/A-002-B	Classroom 21	11/1/2018	11/5/2018	A8K0049-04	Copper	0.0282	0.00200	1.3	ppm
290-CH1234-N/A-002-B	Classroom 21	11/1/2018	11/5/2018	A8K0049-04	Lead	0.760	0.200	15	ppb
290-CH1235-N/A-002-A	Classroom 17	11/1/2018	11/5/2018	A8K0049-07	Copper	0.0591	0.00200	1.3	ppm
290-CH1235-N/A-002-A	Classroom 17	11/1/2018	11/5/2018	A8K0049-07	Lead	2.66	0.200	15	ppb
290-CH1235-N/A-002-B	Classroom 17	11/1/2018	11/5/2018	A8K0049-08	Copper	0.0284	0.00200	1.3	ppm
290-CH1235-N/A-002-B	Classroom 17	11/1/2018	11/5/2018	A8K0049-08	Lead	0.772	0.200	15	ppb
290-CH1238-N/A-002-A	Classroom 13	11/1/2018	11/5/2018	A8K0049-13	Copper	0.0538	0.00200	1.3	ppm
290-CH1238-N/A-002-A	Classroom 13	11/1/2018	11/5/2018	A8K0049-13	Lead	4.15	4.00	15	ppb
290-CH1238-N/A-002-B	Classroom 13	11/1/2018	11/5/2018	A8K0049-14	Copper	0.0304	0.00200	1.3	ppm
290-CH1238-N/A-002-B	Classroom 13	11/1/2018	11/5/2018	A8K0049-14RE1	Lead	1.30	0.200	15	ppb
290-CH1240-N/A-002-A	Classroom 23	11/1/2018	11/5/2018	A8K0049-01	Copper	0.0312	0.00200	1.3	ppm
290-CH1240-N/A-002-A	Classroom 23	11/1/2018	11/5/2018	A8K0049-01	Lead	8.54	0.200	15	ppb
290-CH1240-N/A-002-B	Classroom 23	11/1/2018	11/5/2018	A8K0049-02	Copper	0.0235	0.00200	1.3	ppm
290-CH1240-N/A-002-B	Classroom 23	11/1/2018	11/5/2018	A8K0049-02	Lead	2.81	0.200	15	ppb
290-CH1241-N/A-002-A	Classroom 11	11/1/2018	11/5/2018	A8K0049-15	Copper	0.0499	0.00200	1.3	ppm
290-CH1241-N/A-002-A	Classroom 11	11/1/2018	11/5/2018	A8K0049-15	Lead	6.52	4.00	15	ppb
290-CH1241-N/A-002-B	Classroom 11	11/1/2018	11/5/2018	A8K0049-16	Copper	0.0260	0.00200	1.3	ppm
290-CH1241-N/A-002-B	Classroom 11	11/1/2018	11/5/2018	A8K0049-16RE1	Lead	3.08	0.200	15	ppb

Analyzed by:

290-CH1243-N/A-002-A	Classroom 24	11/1/2018	11/5/2018	A8K0049-19	Copper	0.0516	0.00200	1.3	ppm
290-CH1243-N/A-002-A	Classroom 24	11/1/2018	11/5/2018	A8K0049-19	Lead	4.55	4.00	15	ppb
290-CH1243-N/A-002-B	Classroom 24	11/1/2018	11/5/2018	A8K0049-20	Copper	0.0725	0.00200	1.3	ppm
290-CH1243-N/A-002-B	Classroom 24	11/1/2018	11/5/2018	A8K0049-20RE1	Lead	0.410	0.200	15	ppb
290-CH1257-N/A-002-A	Classroom 2	11/1/2018	11/5/2018	A8K0049-23	Copper	0.0945	0.00200	1.3	ppm
290-CH1257-N/A-002-A	Classroom 2	11/1/2018	11/5/2018	A8K0049-23	Lead	57.8	0.200	15	ppb
290-CH1257-N/A-002-B	Classroom 2	11/1/2018	11/5/2018	A8K0049-24	Copper	0.0180	0.00200	1.3	ppm
290-CH1257-N/A-002-B	Classroom 2	11/1/2018	11/5/2018	A8K0049-24	Lead	24.5	0.200	15	ppb
290-CH1259-N/A-002-A	Classroom 3	11/1/2018	11/5/2018	A8K0049-27	Copper	0.0190	0.00200	1.3	ppm
290-CH1259-N/A-002-A	Classroom 3	11/1/2018	11/5/2018	A8K0049-27RE1	Lead	3.16	0.200	15	ppb
290-CH1259-N/A-002-B	Classroom 3	11/1/2018	11/5/2018	A8K0049-28	Copper	0.00683	0.00200	1.3	ppm
290-CH1259-N/A-002-B	Classroom 3	11/1/2018	11/5/2018	A8K0049-28RE1	Lead	0.964	0.200	15	ppb
290-CH1260-N/A-002-A	Classroom 1	11/1/2018	11/5/2018	A8K0049-25	Copper	0.0338	0.00200	1.3	ppm
290-CH1260-N/A-002-A	Classroom 1	11/1/2018	11/5/2018	A8K0049-25	Lead	5.98	4.00	15	ppb
290-CH1260-N/A-002-B	Classroom 1	11/1/2018	11/5/2018	A8K0049-26	Copper	0.00463	0.00200	1.3	ppm
290-CH1260-N/A-002-B	Classroom 1	11/1/2018	11/5/2018	A8K0049-26RE1	Lead	2.58	0.200	15	ppb
290-CH1262-N/A-002-A	Classroom 4	11/1/2018	11/5/2018	A8K0049-29	Copper	0.0186	0.00200	1.3	ppm
290-CH1262-N/A-002-A	Classroom 4	11/1/2018	11/5/2018	A8K0049-29	Lead	4.10	4.00	15	ppb
290-CH1262-N/A-002-B	Classroom 4	11/1/2018	11/5/2018	A8K0049-30	Copper	0.00925	0.00200	1.3	ppm
290-CH1262-N/A-002-B	Classroom 4	11/1/2018	11/5/2018	A8K0049-30RE1	Lead	0.958	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 3 of 4

290-CH1263-N/A-002-A	Classroom 5	11/1/2018	11/5/2018	A8K0049-31	Copper	0.00663	0.00200	1.3	ppm
290-CH1263-N/A-002-A	Classroom 5	11/1/2018	11/5/2018	A8K0049-31RE1	Lead	4.25	0.200	15	ppb
290-CH1263-N/A-002-B	Classroom 5	11/1/2018	11/5/2018	A8K0049-32	Copper	ND	0.00200	1.3	ppm
290-CH1263-N/A-002-B	Classroom 5	11/1/2018	11/5/2018	A8K0049-32RE1	Lead	1.85	0.200	15	ppb
290-CH1266-N/A-002-A	Classroom 7	11/1/2018	11/5/2018	A8K0049-33	Copper	0.0186	0.00200	1.3	ppm
290-CH1266-N/A-002-A	Classroom 7	11/1/2018	11/5/2018	A8K0049-33	Lead	5.13	0.200	15	ppb
290-CH1266-N/A-002-B	Classroom 7	11/1/2018	11/5/2018	A8K0049-34	Copper	0.00492	0.00200	1.3	ppm
290-CH1266-N/A-002-B	Classroom 7	11/1/2018	11/5/2018	A8K0049-34	Lead	3.54	0.200	15	ppb
290-CH1267-N/A-002-A	Classroom 8	11/1/2018	11/5/2018	A8K0049-35	Copper	0.0304	0.00200	1.3	ppm
290-CH1267-N/A-002-A	Classroom 8	11/1/2018	11/5/2018	A8K0049-35	Lead	31.2	0.200	15	ppb
290-CH1267-N/A-002-B	Classroom 8	11/1/2018	11/5/2018	A8K0049-36	Copper	0.00375	0.00200	1.3	ppm
290-CH1267-N/A-002-B	Classroom 8	11/1/2018	11/5/2018	A8K0049-36	Lead	16.1	0.200	15	ppb
290-CH1268-N/A-002-A	Classroom 9	11/1/2018	11/5/2018	A8K0049-37	Copper	0.00472	0.00200	1.3	ppm
290-CH1268-N/A-002-A	Classroom 9	11/1/2018	11/5/2018	A8K0049-37	Lead	5.54	0.200	15	ppb
290-CH1268-N/A-002-B	Classroom 9	11/1/2018	11/5/2018	A8K0049-38	Copper	ND	0.00200	1.3	ppm
290-CH1268-N/A-002-B	Classroom 9	11/1/2018	11/5/2018	A8K0049-38	Lead	3.31	0.200	15	ppb
290-CH1270-N/A-002-A	Classroom 25	11/1/2018	11/5/2018	A8K0049-21	Copper	0.00434	0.00200	1.3	ppm
290-CH1270-N/A-002-A	Classroom 25	11/1/2018	11/5/2018	A8K0049-21RE1	Lead	0.331	0.200	15	ppb
290-CH1270-N/A-002-B	Classroom 25	11/1/2018	11/5/2018	A8K0049-22	Copper	0.00235	0.00200	1.3	ppm
290-CH1270-N/A-002-B	Classroom 25	11/1/2018	11/5/2018	A8K0049-22RE1	Lead	ND	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: