

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Wilcox Administration - Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
292-CH1402-N/A-001-A	Staff Room (Across Room 2)	4/18/2019	4/24/2019	A9D0757-01	Lead	7.84	0.20	15	ppb
292-CH1405-N/A-001-A	Classroom 3	4/18/2019	4/24/2019	A9D0757-02	Lead	0.988	0.20	15	ppb
292-CH1383-N/A-001-A	Classroom 4	4/18/2019	4/24/2019	A9D0757-03	Lead	3.26	0.20	15	ppb
292-CH1386-N/A-001-A	Classroom 5	4/18/2019	4/24/2019	A9D0757-04	Lead	20.40	0.20	15	ppb
292-CH1389-N/A-001-A	Classroom 11	4/18/2019	4/24/2019	A9D0757-05	Lead	1.68	0.20	15	ppb
292-CH1392-N/A-001-A	Classroom 10	4/18/2019	4/24/2019	A9D0757-06	Lead	2.9	0.20	15	ppb
292-CH1395-N/A-001-A	Classroom 9	4/18/2019	4/24/2019	A9D0757-07	Lead	25.30	0.20	15	ppb
292-CH1398-N/A-001-A	Classroom 8	4/18/2019	4/25/2019	A9D0757-08	Lead	41.10	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.