

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Wilson High School

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
126-CH1905-A-004-A	Kitchen	11/7/2018	11/12/2018	A8K0271-01	Copper	0.0537	0.00200	1.3	ppm
126-CH1905-A-004-A	Kitchen	11/7/2018	11/12/2018	A8K0271-01	Lead	4.66	0.200	15	ppb
126-CH1905-A-004-B	Kitchen	11/7/2018	11/12/2018	A8K0271-02	Copper	0.0445	0.00200	1.3	ppm
126-CH1905-A-004-B	Kitchen	11/7/2018	11/12/2018	A8K0271-02	Lead	0.760	0.200	15	ppb
126-CH1905-B-004-A	Kitchen	11/7/2018	11/12/2018	A8K0271-03	Copper	0.0506	0.00200	1.3	ppm
126-CH1905-B-004-A	Kitchen	11/7/2018	11/12/2018	A8K0271-03	Lead	2.01	0.200	15	ppb
126-CH1905-B-004-B	Kitchen	11/7/2018	11/12/2018	A8K0271-04	Copper	0.0492	0.00200	1.3	ppm
126-CH1905-B-004-B	Kitchen	11/7/2018	11/12/2018	A8K0271-04RE1	Lead	0.365	0.200	15	ppb
126-CH1910-N/A-004-A	Cafeteria	11/7/2018	11/12/2018	A8K0271-05	Copper	0.0331	0.00200	1.3	ppm
126-CH1910-N/A-004-A	Cafeteria	11/7/2018	11/12/2018	A8K0271-05	Lead	19.8	0.200	15	ppb
126-CH1910-N/A-004-B	Cafeteria	11/7/2018	11/12/2018	A8K0271-06	Copper	0.00520	0.00200	1.3	ppm
126-CH1910-N/A-004-B	Cafeteria	11/7/2018	11/12/2018	A8K0271-06	Lead	6.20	0.200	15	ppb
126-CH1914-N/A-004-A	Room 7	11/7/2018	11/12/2018	A8K0271-07	Copper	0.262	0.00200	1.3	ppm
126-CH1914-N/A-004-A	Room 7	11/7/2018	11/12/2018	A8K0271-07	Lead	32.9	0.200	15	ppb
126-CH1914-N/A-004-B	Room 7	11/7/2018	11/12/2018	A8K0271-08	Copper	0.0524	0.00200	1.3	ppm
126-CH1914-N/A-004-B	Room 7	11/7/2018	11/12/2018	A8K0271-08	Lead	7.32	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

126-CH1900-A-004-A	Hallway 30A	11/7/2018	11/12/2018	A8K0271-09	Copper	0.0271	0.00200	1.3	ppm
126-CH1900-A-004-A	Hallway 30A	11/7/2018	11/12/2018	A8K0271-09	Lead	6.37	0.200	15	ppb
126-CH1900-A-004-B	Hallway 30A	11/7/2018	11/12/2018	A8K0271-10	Copper	0.0200	0.00200	1.3	ppm
126-CH1900-A-004-B	Hallway 30A	11/7/2018	11/12/2018	A8K0271-10	Lead	6.24	0.200	15	ppb
126-CH1900-B-004-A	Hallway 30A	11/7/2018	11/12/2018	A8K0271-11	Copper	0.0192	0.00200	1.3	ppm
126-CH1900-B-004-A	Hallway 30A	11/7/2018	11/12/2018	A8K0271-11	Lead	7.00	0.200	15	ppb
126-CH1900-B-004-B	Hallway 30A	11/7/2018	11/12/2018	A8K0271-12RE1	Copper	0.0143	0.00200	1.3	ppm
126-CH1900-B-004-B	Hallway 30A	11/7/2018	11/12/2018	A8K0271-12RE1	Lead	7.35	0.200	15	ppb
126-CH1899-C-004-A	Hallway 21	11/7/2018	11/12/2018	A8K0271-13	Copper	0.0999	0.00200	1.3	ppm
126-CH1899-C-004-A	Hallway 21	11/7/2018	11/12/2018	A8K0271-13	Lead	3.78	0.200	15	ppb
126-CH1899-C-004-B	Hallway 21	11/7/2018	11/12/2018	A8K0271-14	Copper	0.123	0.00200	1.3	ppm
126-CH1899-C-004-B	Hallway 21	11/7/2018	11/12/2018	A8K0271-14	Lead	1.38	0.200	15	ppb
126-CH1899-D-004-A	Hallway 21	11/7/2018	11/12/2018	A8K0271-15	Copper	0.154	0.00200	1.3	ppm
126-CH1899-D-004-A	Hallway 21	11/7/2018	11/12/2018	A8K0271-15	Lead	3.19	0.200	15	ppb
126-CH1899-D-004-B	Hallway 21	11/7/2018	11/12/2018	A8K0271-16	Copper	0.154	0.00200	1.3	ppm
126-CH1899-D-004-B	Hallway 21	11/7/2018	11/12/2018	A8K0271-16	Lead	0.404	0.200	15	ppb
126-CH1895-N/A-004-A	Apparatus Room	11/7/2018	11/12/2018	A8K0271-17	Copper	0.0435	0.00200	1.3	ppm
126-CH1895-N/A-004-A	Apparatus Room	11/7/2018	11/12/2018	A8K0271-17	Lead	3.95	0.200	15	ppb
126-CH1895-N/A-004-B	Apparatus Room	11/7/2018	11/12/2018	A8K0271-18	Copper	0.0101	0.00200	1.3	ppm
126-CH1895-N/A-004-B	Apparatus Room	11/7/2018	11/12/2018	A8K0271-18	Lead	0.683	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

126-CH1894-N/A-004-A	Apparatus Room	11/7/2018	11/12/2018	A8K0271-19	Copper	0.162	0.00200	1.3	ppm
126-CH1894-N/A-004-A	Apparatus Room	11/7/2018	11/12/2018	A8K0271-19	Lead	12.6	0.200	15	ppb
126-CH1894-N/A-004-B	Apparatus Room	11/7/2018	11/12/2018	A8K0271-20	Copper	0.0111	0.00200	1.3	ppm
126-CH1894-N/A-004-B	Apparatus Room	11/7/2018	11/12/2018	A8K0271-20	Lead	7.55	0.200	15	ppb
126-CH1897-N/A-004-A	Vomen's Locker Roor	11/7/2018	11/12/2018	A8K0271-21	Copper	0.0282	0.00200	1.3	ppm
126-CH1897-N/A-004-A	Vomen's Locker Roor	11/7/2018	11/12/2018	A8K0271-21	Lead	12.2	0.200	15	ppb
126-CH1897-N/A-004-B	Vomen's Locker Roor	11/7/2018	11/12/2018	A8K0271-22	Copper	0.0466	0.00200	1.3	ppm
126-CH1897-N/A-004-B	Vomen's Locker Roor	11/7/2018	11/12/2018	A8K0271-22	Lead	15.3	0.200	15	ppb
126-CH1929-N/A-004-A	Room 247	11/7/2018	11/12/2018	A8K0271-23	Copper	0.0306	0.00200	1.3	ppm
126-CH1929-N/A-004-A	Room 247	11/7/2018	11/12/2018	A8K0271-23	Lead	24.3	0.200	15	ppb
126-CH1929-N/A-004-B	Room 247	11/7/2018	11/12/2018	A8K0271-24RE1	Copper	0.0306	0.00200	1.3	ppm
126-CH1929-N/A-004-B	Room 247	11/7/2018	11/12/2018	A8K0271-24RE1	Lead	8.01	0.200	15	ppb
126-CH1931-N/A-004-A	Room 246	11/7/2018	11/12/2018	A8K0271-25	Copper	0.0353	0.00200	1.3	ppm
126-CH1931-N/A-004-A	Room 246	11/7/2018	11/12/2018	A8K0271-25	Lead	38.9	0.200	15	ppb
126-CH1931-N/A-004-B	Room 246	11/7/2018	11/12/2018	A8K0271-26	Copper	0.0396	0.00200	1.3	ppm
126-CH1931-N/A-004-B	Room 246	11/7/2018	11/12/2018	A8K0271-26	Lead	21.8	0.200	15	ppb
126-CH1933-D-004-A	Hallway 218	11/7/2018	11/12/2018	A8K0271-27	Copper	0.125	0.00200	1.3	ppm
126-CH1933-D-004-A	Hallway 218	11/7/2018	11/12/2018	A8K0271-27	Lead	1.77	0.200	15	ppb
126-CH1933-D-004-B	Hallway 218	11/7/2018	11/12/2018	A8K0271-28	Copper	0.168	0.00200	1.3	ppm
126-CH1933-D-004-B	Hallway 218	11/7/2018	11/12/2018	A8K0271-28	Lead	1.21	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

126-CH1934-A-004-A	Hallway 209	11/7/2018	11/12/2018	A8K0271-29	Copper	0.0376	0.00200	1.3	ppm
126-CH1934-A-004-A	Hallway 209	11/7/2018	11/12/2018	A8K0271-29	Lead	37.4	0.200	15	ppb
126-CH1934-A-004-B	Hallway 209	11/7/2018	11/12/2018	A8K0271-30	Copper	0.0409	0.00200	1.3	ppm
126-CH1934-A-004-B	Hallway 209	11/7/2018	11/12/2018	A8K0271-30	Lead	52.8	0.200	15	ppb
126-CH1934-C-004-A	Hallway 209	11/7/2018	11/12/2018	A8K0271-31	Copper	0.0216	0.00200	1.3	ppm
126-CH1934-C-004-A	Hallway 209	11/7/2018	11/12/2018	A8K0271-31	Lead	9.18	0.200	15	ppb
126-CH1934-C-004-B	Hallway 209	11/7/2018	11/12/2018	A8K0271-32	Copper	0.0175	0.00200	1.3	ppm
126-CH1934-C-004-B	Hallway 209	11/7/2018	11/12/2018	A8K0271-32	Lead	7.16	0.200	15	ppb
126-CH1928-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-33	Copper	0.540	0.00200	1.3	ppm
126-CH1928-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-33	Lead	44.7	0.200	15	ppb
126-CH1928-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-34	Lead	190	0.200	15	ppb
126-CH1928-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-34RE1	Copper	2.86	0.0200	1.3	ppm
126-CH1916-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-35	Copper	0.216	0.00200	1.3	ppm
126-CH1916-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-35	Lead	18.7	0.200	15	ppb
126-CH1916-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-36	Copper	0.236	0.00200	1.3	ppm
126-CH1916-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-36	Lead	16.7	0.200	15	ppb
126-CH1915-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-37	Copper	0.0526	0.00200	1.3	ppm
126-CH1915-N/A-004-A	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-37	Lead	19.6	0.200	15	ppb
126-CH1915-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-38	Copper	0.0527	0.00200	1.3	ppm
126-CH1915-N/A-004-B	Hallway and Foyer	11/7/2018	11/12/2018	A8K0271-38	Lead	2.35	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

126-CH1920-A-004-A	Hallway 104	11/7/2018	11/12/2018	A8K0271-39	Copper	0.0103	0.00200	1.3	ppm
126-CH1920-A-004-A	Hallway 104	11/7/2018	11/12/2018	A8K0271-39	Lead	27.1	0.200	15	ppb
126-CH1920-A-004-B	Hallway 104	11/7/2018	11/12/2018	A8K0271-40	Copper	0.00494	0.00200	1.3	ppm
126-CH1920-A-004-B	Hallway 104	11/7/2018	11/12/2018	A8K0271-40	Lead	28.2	0.200	15	ppb
126-CH1920-B-004-A	Hallway 104	11/7/2018	11/12/2018	A8K0271-41	Copper	0.00631	0.00200	1.3	ppm
126-CH1920-B-004-A	Hallway 104	11/7/2018	11/12/2018	A8K0271-41	Lead	17.3	0.200	15	ppb
126-CH1920-B-004-B	Hallway 104	11/7/2018	11/12/2018	A8K0271-42	Copper	0.00309	0.00200	1.3	ppm
126-CH1920-B-004-B	Hallway 104	11/7/2018	11/12/2018	A8K0271-42	Lead	15.1	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.