

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Wilson - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
126-CH1900-A-005-A	Hallway (30A)	3/28/2109	4/9/2109	A9C1074-01	Lead	4.73	0.20	15	ppb
126-CH1900-B-005-A	Hallway (30A)	3/28/2109	4/9/2109	A9C1074-03	Lead	2.15	0.20	15	ppb
126-CH1900-C-005-A	Hallway (30A)	3/28/2109	4/9/2109	A9C1074-05	Lead	49.30	0.20	15	ppb
126-CH1898-N/A-005-A	Hallway (34)	3/28/2109	4/9/2109	A9C1074-07	Lead	3.21	0.20	15	ppb
126-CH1896-N/A-005-A	Gym Wrestling Room	3/28/2109	4/9/2109	A9C1074-09	Lead	288.00	0.20	15	ppb
126-CH1933-C-005-A	Hallway (218)	3/28/2109	4/9/2109	A9C1074-11	Lead	0.978	0.20	15	ppb
126-CH1933-D-005-A	Hallway (218)	3/28/2109	4/9/2109	A9C1074-13	Lead	0.764	0.20	15	ppb
126-CH1934-A-005-A	Hallway (209)	3/28/2109	4/9/2109	A9C1074-15	Lead	34.20	0.20	15	ppb
126-CH1934-B-005-A	Hallway (209)	3/28/2109	4/9/2109	A9C1074-17	Lead	14.3	0.20	15	ppb
126-CH1934-C-005-A	Hallway (209)	3/28/2109	4/9/2109	A9C1074-19	Lead	13.5	0.20	15	ppb
126-CH1934-D-005-A	Hallway (209)	3/28/2109	4/9/2109	A9C1074-21	Lead	14.6	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.